


Esquema frigorífico de los equipos instalados


Sistema 2
LREQ5BY1



15,0m [5]
 $\frac{3}{8}$ " x $\frac{7}{8}$ "

KHRQ22M20T

12,0m [0]
 $\frac{1}{4}$ " x $\frac{1}{2}$ "



15,0m [5]
 $\frac{3}{8}$ " x $\frac{5}{8}$ "


KHRQ22M20T

10,0m [3]
 $\frac{3}{8}$ " x $\frac{5}{8}$ "

cámara


KHRQ22M20T

10,0m [4]
 $\frac{1}{4}$ " x $\frac{1}{2}$ "




semimural

10,0m [4]
 $\frac{1}{4}$ " x $\frac{1}{2}$ "



semimural

10,0m [4]
 $\frac{1}{4}$ " x $\frac{1}{2}$ "



semimural