



-  No heatpump operation.
-  In this area the minimum watervolume must be increased to 40l
- (*) In case ambient temperatures below 0°C are likely to happen, we recommend to use
 - * Glycol (for more information, see installation manual),
 - or
 - * OP10 (Insulation+ heatertape around the waterpiping).