

Options

Item	Model		FWF02-05B
1	Decoration Panel	(RAL 9010 - grey sealings)	4-way blow
2	Sealing member of air discharge outlet		KDBH44BA60
3	Panel spacer		KDBQ44B60
4	Long-life filter		KAQ441BA60
5	Fresh air intake kit	Direct installation type	KDDQ44XA60

Control system

Item	Model		FWF02-05B
1	Remote control	Infrared	H/P
			C/O
		Wired	
2	Central remote control		BRC7E530 (*12)
2.1	Electrical box with earth terminal (3 blocks)		BRC7E531 (*12)
3	Unified on/off controller		BRC315D7 (*1)
3.1	Electrical box with earth terminal (2 blocks)		DCS302CA51 (*2)
4	Schedule timer		KJB311A
5	Wiring adapter for electrical appendices (1)		DCS301BA51 (*5)
6	Wiring adapter for electrical appendices (2)		KJB212A
7	Installation box for adapter PCB		DST301BA51 (*5)(*8)
8	Remote sensor		KRP2A52 (*4)(*8)
10	Intelligent touch controller		KRP4AA53 (*4)(*8)
10.1	Electrical installation box		KRP1BA101 (*9)
11	Optional PCB for MOD-bus connection		KRCS01-1
12	2-way valve - On/Off		DCS601C51C (*3)(*7)
13	3-way valve - On/Off		KJB411A
14	Valve control PCB		EKFCMBCB7 (*4)(*8)
15	Remote "On/Off" and "forced off" kit		EKMV2C09B7 (*4)(*6)(*10)
			EKRV3C09B7 (*4)(*6)(*10)
			EKRP1C11
			EKROROA (*11)

NOTES

- *1. Optional, electrical installation box with earth terminal KJB212A is required, if controller wires need to be installed in the wall.
- *2. Requires electrical installation box with earth terminal KJB311A.
- *3. Requires electrical installation box KJB411A.
- *4. Requires installation box KRP1BA101.
- *5. Requires electrical installation box with earth terminal KJB212A if built in the wall.
- *6. Requires valve control PCB EKRP1C11.
- *7. I-touch:
- Not allowed to use the i-touch for an installation with both fan coils and VRV® units.
 - Can not be used in combination with fan coil units, that use MOD bus communication.
 - No Airnet or telephone connection possible.
- *8. Only 1 of these 4 options can be installed on 1 indoor unit.
- *9. Max. 2 KRP1BA101 boxes can be mounted on the unit. Max. 1 PCB can be mounted in 1 KRP1BA101 box.
- *10. 2-pipe unit: 1 x valve kit + 1 x installation box for PCB KRP1BA101 + 1 x valve control PCB EKRP1C11
4-pipe unit: 2 x valve kit + 1 x installation box for PCB KRP1BA101 + 1 x valve control PCB EKRP1C11
- *11. This option is needed to create T1 T2 wire.
- *12. It is possible to change the operation mode, but this will not have an impact on the water temperature.
(No feed back to water source)
It is not possible to select the "auto air flow" setting.
Dry operation can be selected with this remote control, but this function is not available on the FWF model.
- *13. All options are supplied as kit.