

FWV-DAT
FWL-DAT
FWM-DAT

Air Temperature (°C)		22											
Water Temperature (Entering °C - leaving °C)		45 40			60 50			70 60			90 70		
Model		Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop
		W	l/h	kPa	W	l/h	kPa	W	l/h	kPa	W	l/h	kPa
FW 01 T	Max	1650	287	13	2670	233	8	3530	310	13	4750	210	7
	Med	1330	232	9	2160	189	6	2850	250	9	3860	170	5
	Min	1100	191	6	1780	156	4	2350	206	7	3190	141	3
FW 15 T	Max	1670	290	11	2690	235	7	3560	313	12	4790	211	6
	Med	1560	272	10	2530	221	7	3330	292	11	4510	199	5
	Min	1310	228	7	2130	186	5	2790	245	8	3800	168	4
FW 02 T	Max	1950	338	10	3150	275	7	4140	363	10	5610	248	5
	Med	1640	285	7	2660	233	5	3500	307	8	4760	210	4
	Min	1360	236	5	2210	193	4	2890	254	6	3950	174	3
FW 25 T	Max	2450	425	14	3960	346	9	5210	457	15	7050	311	7
	Med	2050	356	10	3320	290	7	4350	381	11	5920	261	5
	Min	1580	274	7	2560	224	4	3350	294	7	4590	203	3
FW 03 T	Max	2900	505	9	4730	413	6	6150	540	10	8430	372	5
	Med	2340	407	7	3820	334	4	4970	436	7	6840	302	3
	Min	1730	302	4	2840	248	3	3670	322	4	5090	225	2
FW 35 T	Max	3670	638	11	5940	519	7	7820	686	12	10590	467	6
	Med	2840	494	7	4620	403	5	6040	529	7	8240	364	4
	Min	2160	376	4	3520	308	3	4600	404	5	6330	279	2
FW 04 T	Max	3840	668	9	6210	543	6	8160	716	9	11050	488	4
	Med	2930	510	5	4750	415	4	6250	548	6	8500	376	3
	Min	2240	389	3	3630	318	2	4780	420	3	6510	287	2
FW 06 T	Max	4510	785	11	7310	639	7	9590	841	11	13020	575	6
	Med	3700	643	8	6010	525	5	7850	689	8	10710	473	4
	Min	3000	521	5	4880	426	4	6380	560	6	8730	386	3
FW 08 T	Max	5890	1024	8	9550	834	5	12500	1097	9	17000	750	4
	Med	4680	813	6	7600	664	4	9960	874	6	13580	600	3
	Min	3590	625	3	5840	510	2	7670	673	4	10460	462	2
FW 10 T	Max	7610	1323	16	12320	1077	10	16190	1420	16	21920	968	8
	Med	5920	1029	10	9600	839	7	12570	1102	10	17080	754	5
	Min	3980	692	5	6460	565	3	8490	744	5	11570	511	3