

FWV-DAT
FWL-DAT
FWM-DAT

Air Temperature (°C)		20											
Water Temperature (Entering °C - leaving °C)		45- 40			60 - 50			70 - 60			90 - 70		
Model		Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop
		W	l/h	kPa	W	l/h	kPa	W	l/h	kPa	W	l/h	kPa
FW 01 T	Max	1820	317	15	2840	249	10	3710	325	15	4940	218	7
	Med	1480	256	11	2310	201	7	2990	263	10	4010	177	5
	Min	1210	211	8	1900	166	5	2470	216	7	3320	147	3
FW 15 T	Max	1840	320	14	2870	251	8	3740	329	13	4970	219	6
	Med	1720	300	12	2700	236	7	3500	307	11	4690	207	5
	Min	1450	252	9	2270	198	6	2930	257	8	3950	174	4
FW 02 T	Max	2150	373	12	3360	293	7	4350	382	11	5830	257	5
	Med	1810	315	9	2840	248	6	3670	322	8	4940	218	4
	Min	1500	260	6	2350	206	4	3040	267	6	4110	181	3
FW 25 T	Max	2700	469	17	4220	369	10	5470	480	16	7320	323	8
	Med	2260	393	12	3540	309	8	4570	401	12	6150	271	6
	Min	1740	302	8	2730	239	5	3520	308	7	4760	210	4
FW 03 T	Max	3200	556	11	5030	439	7	6460	567	11	8760	386	5
	Med	2580	449	8	4070	356	5	5220	458	7	7110	314	4
	Min	1910	332	5	3020	264	3	3860	339	4	5290	233	2
FW 35 T	Max	4050	704	13	6330	553	8	8210	720	13	11000	486	6
	Med	3130	545	8	4920	430	5	6340	556	8	8550	378	4
	Min	2390	415	5	3760	328	3	4830	424	5	6570	290	2
FW 04 T	Max	4240	736	10	6620	578	6	8570	752	10	11480	507	5
	Med	3240	563	6	5070	443	4	6570	576	6	8840	390	3
	Min	2470	430	4	3880	339	2	5030	441	4	6760	299	2
FW 06 T	Max	4980	865	13	7790	681	8	10080	884	12	13520	597	6
	Med	4080	709	9	6400	559	6	8250	724	9	11120	491	4
	Min	3310	576	6	5200	454	4	6700	588	6	9070	400	3
FW 08 T	Max	6490	1129	10	10170	889	6	13130	1152	9	17650	779	4
	Med	5170	898	7	8100	708	4	10460	918	6	14100	623	3
	Min	3970	690	4	6230	544	3	8060	707	4	10880	480	2
FW 10 T	Max	8400	1460	19	13130	1147	11	17000	1492	18	22760	1005	8
	Med	6530	1135	12	10220	893	7	13200	1158	11	17740	783	5
	Min	4390	764	6	6890	602	4	8910	782	6	12020	531	3