

	ESP	10		20		30		40		50		60		
		Fan Speed	F1	F2	F1	F2								
FW01	max	0.86	0.91	0.72	0.80	0.56	0.67	-	-	-	-	-	-	-
	med	0.78	0.84	0.56	0.65	0.33	0.41	-	-	-	-	-	-	-
	min	0.71	0.77	0.35	0.40	-	-	-	-	-	-	-	-	-
FW15	max	0.88	0.92	0.76	0.83	0.65	0.74	0.53	0.64	0.42	0.53	0.31	0.41	
	med	0.83	0.88	0.68	0.75	0.54	0.63	0.40	0.49	0.27	0.38	-	-	
	min	0.79	0.83	0.59	0.65	0.38	0.48	0.17	0.27	-	-	-	-	
FW02	max	0.85	0.89	0.73	0.78	0.61	0.67	0.5	0.57	0.40	0.47	0.31	0.36	
	med	0.82	0.85	0.63	0.68	0.45	0.50	0.27	0.30	-	-	-	-	
	min	0.78	0.80	0.55	0.59	0.35	0.37	-	-	-	-	-	-	
FW25	max	0.91	0.94	0.81	0.86	0.69	0.77	0.56	0.66	0.4	0.5	0.18	0.28	
	med	0.86	0.89	0.70	0.76	0.54	0.61	0.36	0.44	0.15	0.24	-	-	
	min	0.80	0.83	0.55	0.60	0.22	0.31	-	-	-	-	-	-	
FW03	max	0.89	0.91	0.77	0.81	0.64	0.69	0.51	0.56	0.36	0.40	0.18	0.21	
	med	0.82	0.84	0.64	0.67	0.47	0.50	0.29	0.32	-	-	-	-	
	min	0.75	0.77	0.48	0.50	-	-	-	-	-	-	-	-	
FW35	max	0.93	0.95	0.85	0.89	0.76	0.81	0.66	0.73	0.54	0.61	0.37	0.44	
	med	0.90	0.92	0.80	0.83	0.69	0.72	0.56	0.60	0.42	0.51	0.24	0.36	
	min	0.83	0.83	0.67	0.73	0.49	0.61	0.31	0.44	-	-	-	-	
FW04	max	0.93	0.95	0.85	0.89	0.77	0.82	0.67	0.73	0.56	0.63	0.42	0.50	
	med	0.91	0.93	0.81	0.84	0.71	0.75	0.59	0.64	0.46	0.51	0.31	0.35	
	min	0.84	0.86	0.68	0.71	0.52	0.55	0.34	0.36	-	-	-	-	
FW06	max	0.93	0.95	0.85	0.89	0.77	0.81	0.67	0.73	0.56	0.62	0.41	0.47	
	med	0.92	0.93	0.82	0.86	0.73	0.77	0.61	0.66	0.48	0.53	0.31	0.36	
	min	0.86	0.88	0.71	0.74	0.56	0.59	0.40	0.43	0.23	0.25	-	-	
FW08	max	0.96	0.96	0.91	0.92	0.86	0.88	0.80	0.83	0.74	0.78	0.67	0.71	
	med	0.95	0.96	0.90	0.92	0.85	0.87	0.79	0.81	0.73	0.76	0.65	0.69	
	min	0.91	0.92	0.81	0.82	0.71	0.73	0.60	0.62	0.49	0.51	0.37	0.39	
FW10	max	0.96	0.97	0.92	0.93	0.87	0.89	0.82	0.85	0.77	0.81	0.72	0.76	
	med	0.95	0.96	0.90	0.91	0.84	0.86	0.78	0.81	0.71	0.75	0.64	0.68	
	min	0.92	0.93	0.84	0.86	0.76	0.78	0.67	0.69	0.57	0.60	0.47	0.50	

		FW01		FW15		FW02		FW025		FW03		FW35		FW4		FW6		FW8		FW10	
		medium	low																		
Total cooling Capacity	TCC	0.81	0.68	0.87	0.72	0.87	0.69	0.84	0.66	0.81	0.60	0.75	0.56	0.76	0.58	0.81	0.66	0.79	0.59	0.78	0.52
Sensible cooling Capacity	SCC	0.81	0.66	0.88	0.73	0.87	0.70	0.84	0.63	0.81	0.60	0.74	0.53	0.78	0.57	0.80	0.64	0.78	0.58	0.77	0.51
Heating Capacity 2 pipe	HC2P	0.81	0.66	0.93	0.78	0.83	0.68	0.84	0.65	0.81	0.59	0.77	0.59	0.76	0.58	0.82	0.66	0.79	0.61	0.78	0.52
Heating Capacity 4 pipe	HC4P	0.85	0.73	0.88	0.77	0.89	0.78	0.87	0.71	0.87	0.71	0.83	0.67	0.83	0.69	0.88	0.76	0.86	0.72	0.85	0.66

Working conditions:

Cooling Air : 27°C DB - 19°C WB - Water : Entering 7°C - leaving 12°C
 Heating 2 pipe Air : 20°C Water : entering 50°C water flow as for cooling
 Heating 4 pipe Air : 20°C Water : entering 70°C - leaving 60°C

F1 = correction factor for air flow
 F2 = correction factor for capacities

Correction factors are based on an average value. This can cause deviation depending on conditions used. The Fan Coil Selection software will provide an accurate result at all conditions.