

Air temperature (°C DB - °C WB)		30 - 22											
Water temperature (Entering °C - leaving °C)		7 - 12				8 - 13				9 - 14			
Model	Total cooling capacity	Sensible cooling capacity		Water flow	Water pressure drop	Sensible cooling capacity		Water flow	Water pressure drop	Sensible cooling capacity		Water flow	Water pressure drop
		W	W			W	W			W	W		
FW 01 FNFV	Max.	2510	1440	430	32	2320	1370	398	27	2120	1300	364	23
	Med.	1970	1150	337	21	1820	1090	312	18	1670	1030	286	15
	Min.	1690	970	290	16	1570	920	269	14	1440	870	246	12
FW 02 FNFV	Max.	3150	1880	540	35	2920	1790	502	31	2690	1700	462	27
	Med.	2660	1570	457	27	2480	1490	425	23	2280	1420	392	20
	Min.	2210	1280	379	19	2060	1220	353	17	1900	1150	326	15
FW 03 FNFV	Max.	4670	2630	802	26	4360	2500	748	23	4030	2370	692	20
	Med.	3790	2130	650	18	3540	2020	607	16	3280	1910	562	14
	Min.	2840	1600	487	11	2660	1520	456	10	2460	1440	422	8
FW 04 FNFV	Max.	6990	3930	1199	29	6510	3740	1117	25	6010	3540	1032	22
	Med.	5330	3080	915	18	4970	2930	853	16	4590	2770	789	14
	Min.	4140	2320	710	11	3860	2200	663	10	3570	2080	613	9
FW 06 FNFV	Max.	7650	4470	1312	33	7130	4260	1224	29	6580	4040	1130	25
	Med.	6250	3630	1073	23	5830	3450	1001	20	5380	3270	925	18
	Min.	5130	2920	880	16	4790	2770	822	14	4430	2620	760	13
FW 08 FNFV	Max.	10760	6140	1846	28	10050	5840	1724	25	9290	5530	1596	21
	Med.	8550	4860	1467	19	7990	4620	1371	17	7390	4370	1269	14
	Min.	6580	3680	1127	12	6140	3490	1054	10	5680	3300	975	9
FW 10 TN/V	Max.	12880	7340	2208	38	12010	7000	2061	34	11090	6640	1904	29
	Med.	10140	5790	1740	25	9450	5510	1622	22	8730	5220	1498	19
	Min.	6900	3920	1183	13	6430	3720	1103	11	5930	3520	1018	10