

FWZ-AT
FWR-AT
FWS-AT

Air Temperature (° C)		20								
Water Temperature (Entering °C - leaving °C)		50 - 45			60 - 50			70 - 60		
Model		Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop
		KW	l/sec	kPa	KW	l/sec	kPa	KW	l/sec	kPa
FW 02 T	Max	3.61	0.175	29	4.56	0.111	13	5.94	0.145	20
	Min	0.69	0.033	2	0.90	0.022	1	1.15	0.028	1
FW 03 T	Max	6.62	0.321	39	8.40	0.204	17	10.91	0.266	27
	Min	0.95	0.046	1	1.26	0.030	1	1.59	0.039	1
FW 06 T	Max	7.93	0.384	29	10.43	0.243	13	13.05	0.318	20
	Min	1.29	0.063	1	1.69	0.041	1	2.15	0.052	1
FW 08 T	Max	11.32	0.548	32	14.35	0.348	14	18.63	0.454	22
	Min	1.93	0.930	1	2.48	0.060	1	3.20	0.078	1

Air flow at 0Pa