

FWZ-AT
FWR-AT
FWS-AT

Air Temperature (°C)		22								
Water Temperature (Entering °C - leaving °C)		50 - 45			60 - 50			70 - 60		
Model		Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop	Heating capacity	Water flow	Water pressure drop
		KW	l/sec	kPa	KW	l/sec	kPa	KW	l/sec	kPa
FW 02 T	Max	3.33	0.161	25	4.27	0.104	11	5.66	0.138	18
	Min	0.06	0.031	1	0.09	0.021	1	1.09	0.027	1
FW 03 T	Max	6.11	0.296	34	7.88	0.191	16	10.38	0.253	24
	Min	0.88	0.043	1	1.18	0.029	1	1.51	0.037	1
FW 06 T	Max	7.32	0.354	25	9.41	0.228	11	12.42	0.303	18
	Min	1.20	0.058	1	1.59	0.039	1	2.05	0.050	1
FW 08 T	Max	10.45	0.506	28	13.46	0.327	13	17.74	0.432	20
	Min	1.78	0.086	1	2.33	0.056	1	3.05	0.074	1

Air flow at 0Pa