

Indoor unit	Indoor unit connections		Outdoor unit	Quantity	Outdoor unit connections		Piping diameter requirements			
	Gas side Ø	Liquid side Ø			Gas side Ø	Liquid side Ø	G/G1	L/L1	G2	L2
SEHVX20*	25,4	12,7	SERHQ20*	1	22,2	9,52	28,6	9,52	-	-
SEHVX32*			SERHQ32*	1	28,6	12,7		12,7		
SEHVX40*			SERHX20*	2	22,2	9,52		9,52		
SEHVX64*			SERHX32*	2	28,6	12,7		12,7	28,6	9,52
										12,7

Maximum height difference between outdoor unit and indoor unit: ·10·m.

The outdoor units should be installed on the same level

Piping restrictions ·30m·

