

Heating :50Hz 230V~

①	②	Indoor air temperature [°C DB]											
		16°C				18°C				20°C			
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2.5+2.5+4.2+4.2	-20.0	5.27	2.47	5.11	2.52	4.92	2.56	4.89	2.57	4.77	2.57	4.59	2.61
	-15.0	6.47	2.63	6.31	2.67	6.14	2.70	6.09	2.71	5.99	2.72	5.84	2.76
	-10.0	7.67	2.78	7.51	2.81	7.36	2.84	7.29	2.86	7.21	2.88	7.09	2.92
	-5.0	8.89	2.93	8.74	2.96	8.58	3.00	8.51	3.01	8.46	3.02	8.29	3.06
	0.0	10.11	3.08	9.96	3.11	9.83	3.14	9.73	3.15	9.66	3.18	9.51	3.20
	6.0	11.58	3.26	11.43	3.28	11.28	3.32	11.21	3.33	11.13	3.36	10.97	3.38
2.5+2.5+4.2+5.0	-20.0	5.29	2.48	5.12	2.51	4.97	2.53	4.90	2.56	4.82	2.57	4.67	2.61
	-15.0	6.52	2.62	6.36	2.66	6.21	2.68	6.14	2.71	6.06	2.72	5.91	2.76
	-10.0	7.75	2.77	7.60	2.80	7.45	2.84	7.38	2.85	7.30	2.86	7.15	2.90
	-5.0	8.99	2.92	8.84	2.95	8.69	2.98	8.61	3.00	8.54	3.02	8.38	3.05
	0.0	10.23	3.07	10.08	3.11	9.93	3.13	9.85	3.15	9.78	3.17	9.62	3.20
	6.0	11.71	3.25	11.56	3.27	11.41	3.31	11.33	3.32	11.26	3.35	11.11	3.37
2.5+2.5+4.2+6.0	-20.0	5.27	2.47	5.11	2.52	4.92	2.56	4.89	2.57	4.77	2.57	4.59	2.61
	-15.0	6.47	2.63	6.31	2.67	6.14	2.70	6.09	2.71	5.99	2.72	5.84	2.76
	-10.0	7.67	2.78	7.51	2.81	7.36	2.84	7.29	2.86	7.21	2.88	7.09	2.92
	-5.0	8.89	2.93	8.74	2.96	8.58	3.00	8.51	3.01	8.46	3.02	8.29	3.06
	0.0	10.11	3.08	9.96	3.11	9.83	3.14	9.73	3.15	9.66	3.18	9.51	3.20
	6.0	11.58	3.26	11.43	3.28	11.28	3.32	11.21	3.33	11.13	3.36	10.97	3.38
2.5+2.5+5.0+5.0	-20.0	5.29	2.48	5.12	2.51	4.97	2.53	4.90	2.56	4.82	2.57	4.67	2.61
	-15.0	6.52	2.62	6.36	2.66	6.21	2.68	6.14	2.71	6.06	2.72	5.91	2.76
	-10.0	7.75	2.77	7.60	2.80	7.45	2.84	7.38	2.85	7.30	2.86	7.15	2.90
	-5.0	8.99	2.92	8.84	2.95	8.69	2.98	8.61	3.00	8.54	3.02	8.38	3.05
	0.0	10.23	3.07	10.08	3.11	9.93	3.13	9.85	3.15	9.78	3.17	9.62	3.20
	6.0	11.71	3.25	11.56	3.27	11.41	3.31	11.33	3.32	11.26	3.35	11.11	3.37
2.5+3.5+3.5+4.2	-20.0	5.27	2.47	5.11	2.52	4.92	2.56	4.89	2.57	4.77	2.57	4.59	2.61
	-15.0	6.47	2.63	6.31	2.67	6.14	2.70	6.09	2.71	5.99	2.72	5.84	2.76
	-10.0	7.67	2.78	7.51	2.81	7.36	2.84	7.29	2.86	7.21	2.88	7.09	2.92
	-5.0	8.89	2.93	8.74	2.96	8.58	3.00	8.51	3.01	8.46	3.02	8.29	3.06
	0.0	10.11	3.08	9.96	3.11	9.83	3.14	9.73	3.15	9.66	3.18	9.51	3.20
	6.0	11.58	3.26	11.43	3.28	11.28	3.32	11.21	3.33	11.13	3.36	10.97	3.38

①	②	Indoor air temperature [°C DB]											
		16°C				18°C				20°C			
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2.5+3.5+3.5+5.0	-20.0	5.52	2.50	5.37	2.54	5.22	2.57	5.14	2.59	5.07	2.60	4.92	2.64
	-15.0	6.77	2.65	6.62	2.69	6.47	2.72	6.39	2.74	6.31	2.76	6.16	2.79
	-10.0	8.01	2.81	7.86	2.85	7.71	2.87	7.63	2.90	7.56	2.91	7.41	2.95
	-5.0	9.26	2.97	9.11	3.00	8.96	3.04	8.87	3.05	8.80	3.07	8.65	3.10
	0.0	10.50	3.12	10.35	3.16	10.20	3.19	10.12	3.21	10.05	3.23	9.90	3.26
	6.0	11.99	3.32	11.84	3.34	11.69	3.38	11.61	3.39	11.54	3.42	11.38	3.44
2.5+3.5+4.2+4.2	-20.0	5.21	2.47	5.06	2.52	4.93	2.56	4.84	2.57	4.78	2.57	4.63	2.60
	-15.0	6.44	2.63	6.29	2.66	6.15	2.70	6.07	2.71	6.00	2.72	5.85	2.76
	-10.0	7.67	2.78	7.52	2.81	7.37	2.84	7.30	2.85	7.22	2.88	7.06	2.91
	-5.0	8.89	2.93	8.74	2.96	8.59	3.00	8.52	3.01	8.44	3.02	8.29	3.06
	0.0	10.11	3.08	9.96	3.10	9.81	3.14	9.74	3.15	9.66	3.18	9.51	3.20
	6.0	11.58	3.26	11.43	3.28	11.28	3.32	11.21	3.33	11.13	3.36	10.97	3.38
2.5+3.5+4.2+5.0	-20.0	5.28	2.48	5.13	2.51	4.97	2.54	4.89	2.56	4.82	2.57	4.67	2.61
	-15.0	6.51	2.62	6.36	2.66	6.21	2.68	6.13	2.71	6.06	2.72	5.91	2.76
	-10.0	7.75	2.77	7.60	2.80	7.45	2.83	7.37	2.85	7.30	2.86	7.15	2.90
	-5.0	8.99	2.92	8.84	2.95	8.69	2.98	8.61	3.00	8.54	3.02	8.39	3.05
	0.0	10.23	3.07	10.08	3.11	9.93	3.13	9.85	3.15	9.78	3.17	9.63	3.20
	6.0	11.71	3.25	11.56	3.27	11.41	3.31	11.33	3.32	11.26	3.35	11.11	3.37
2.5+4.2+4.2+4.2	-20.0	5.22	2.43	5.06	2.47	4.93	2.51	4.84	2.52	4.78	2.52	4.63	2.55
	-15.0	6.44	2.58	6.29	2.61	6.15	2.65	6.07	2.66	6.00	2.67	5.85	2.71
	-10.0	7.67	2.73	7.52	2.75	7.37	2.79	7.30	2.80	7.22	2.82	7.07	2.86
	-5.0	8.89	2.87	8.74	2.91	8.59	2.94	8.52	2.95	8.44	2.97	8.30	3.00
	0.0	10.11	3.02	9.96	3.05	9.81	3.08	9.74	3.09	9.67	3.12	9.52	3.14
	6.0	11.58	3.20	11.43	3.22	11.28	3.26	11.21	3.27	11.13	3.29	10.97	3.32
3.5+3.5+3.5+3.5	-20.0	5.27	2.47	5.11	2.52	4.92	2.56	4.89	2.57	4.77	2.57	4.59	2.61
	-15.0	6.47	2.63	6.31	2.67	6.14	2.70	6.09	2.71	5.99	2.72	5.84	2.76
	-10.0	7.67	2.78	7.51	2.81	7.36	2.84	7.29	2.86	7.21	2.88	7.09	2.92
	-5.0	8.89	2.93	8.74	2.96	8.58	3.00	8.51	3.01	8.46	3.02	8.29	3.06
	0.0	10.11	3.08	9.96	3.11	9.83	3.14	9.73	3.15	9.66	3.18	9.51	3.20
	6.0	11.58	3.26	11.43	3.28	11.28	3.32	11.21	3.33	11.13	3.36	10.97	3.38
3.5+3.5+3.5+4.2	-20.0	5.29	2.48	5.12	2.51	4.97	2.53	4.90	2.56	4.82	2.57	4.67	2.61
	-15.0	6.52	2.62	6.36	2.66	6.21	2.68	6.14	2.71	6.06	2.72	5.91	2.76
	-10.0	7.75	2.77	7.60	2.80	7.45	2.84	7.38	2.85	7.30	2.86	7.15	2.90
	-5.0	8.99	2.92	8.84	2.95	8.69	2.98	8.61	3.00	8.54	3.02	8.38	3.05
	0.0	10.23	3.07	10.08	3.11	9.93	3.13	9.85	3.15	9.78	3.17	9.62	3.20
	6.0	11.71	3.25	11.56	3.27	11.41	3.31	11.33	3.32	11.26	3.35	11.11	3.37
3.5+3.5+3.5+5.0	-20.0	5.27	2.47	5.11	2.52	4.92	2.56	4.89	2.57	4.77	2.57	4.59	2.61
	-15.0	6.47	2.63	6.31	2.67	6.14	2.70	6.09	2.71	5.99	2.72	5.84	2.76
	-10.0	7.67	2.78	7.51	2.81	7.36	2.84	7.29	2.86	7.21	2.88	7.09	2.92
	-5.0	8.89	2.93	8.74	2.96	8.58	3.00	8.51	3.01	8.46	3.02	8.29	3.06
	0.0	10.11	3.08	9.96	3.11	9.83	3.14	9.73	3.15	9.66	3.18	9.51	3.20
	6.0	11.58	3.26	11.43	3.28	11.28	3.32	11.21	3.33	11.13	3.36	10.97	3.38

Symbols

TC: Total capacity [kW]

PI: Power input [kW]

① Indoor unit combinations

② Outdoor unit temperature [°C WB]