

Datos nominales para los programas de certificación - modo calefacción

Measured according to ·UNI/TS 11300·

Condition	Tamb [°C]	LWC [°C]	PLR [%]	E(B/D)LA04E2(3)V3		E(B/D)LA06E2(3)V3		E(B/D)LA08E2(3)V3	
				HC [kW]	COP	HC [kW]	COP	HC [kW]	COP
A	-7/-8	34	100	5,39	2,90	6,25	2,85	7,28	2,74
B	2/1	30	100	5,60	4,00	6,20	4,05	7,20	3,79
C	7/6	27	100	6,73	5,93	8,18	5,50	9,60	5,25
D	12/11	24	100	6,95	8,31	8,49	7,56	10,02	7,10
A	-7/-8	52	100	4,39	1,54	5,31	1,59	6,91	1,71
B	2/1	42	100	5,35	3,14	6,12	3,00	7,24	2,87
C	7/6	36	100	6,38	4,77	7,71	4,62	9,32	4,38
D	12/11	30	100	6,32	7,35	7,79	7,35	9,52	6,39

Datos nominales para los programas de certificación - modo refrigeración

Measured according to ·UNI/TS 11300·

Condition	Tamb [°C]	LWE [°C]	PLR [%]	EBLA04E2(3)V3		EBLA06E2(3)V3		EBLA08E2(3)V3	
				CC [kW]	EER	CC [kW]	EER	CC [kW]	EER
A	35	18	100	5,98	5,64	7,45	4,84	8,57	4,58
B	30	18	75	4,85	7,31	6,19	6,13	7,23	5,69
C	25	18	50	3,47	8,68	4,54	7,09	5,36	6,38
D*	20	18	25	3,58	9,90	3,58	9,90	3,58	9,90
A	35	7	100	4,62	3,73	5,57	3,48	6,34	3,32
B	30	7	75	3,88	4,76	4,74	4,32	5,37	4,15
C	25	7	50	2,86	5,40	3,53	4,90	3,99	4,69
D*	20	7	25	2,59	6,31	2,59	6,31	2,59	6,31

* Minimum CC that the unit can deliver in part load D