

E(B-D)LQ011-016C3V3_C3W1

Kit availability for *(B/D)LQ*C*

Reference	Description	#
*KCB07CAV3	Control box	(1) o
*KRUCBL1...8C	User interface language group 1...8	(15) o
*KRUCBSC	Simplified user interface	(6) o
*KRSCA1	Remote sensor for outdoor	(3) o
KPCCAB	PC cable kit	(12) o
BRP069A61	LAN adapter for smartphone control + Smart Grid applications	(13) o
BRP069A62	LAN adapter for smartphone control	(13) o

Kit availability for *KCB*C* (1)

Reference	Description	#
*K2CB07CAV3	Option box	(2) o
*KHWCFa	Control board (field supply)	(8) o
FWXV15AVEB	Heat pump convector	(10) o
FWXV20AVEB	Heat pump convector	(10) o
*KVKHPC	Heat pump convector valve kit	(10) o
*KHWS150D*3V3	Domestic hot water tank LT 150 l 1~230V (incl. booster heater)	o
*KHWS180D*3V3	Domestic hot water tank LT 180 l 1~230V (incl. booster heater)	o
*KHWS200D*3V3	Domestic hot water tank LT 200 l 1~230V (incl. booster heater)	o
*KHWS250D*3V3	Domestic hot water tank LT 250 l 1~230V (incl. booster heater)	o
*KHWS300D*3V3	Domestic hot water tank LT 300 l 1~230V (incl. booster heater)	o
*KHWSU150D*3V3	Domestic hot water tank LT 150 l 1~230V (incl. booster heater) (7) (only for UK)	o
*KHWSU180D*3V3	Domestic hot water tank LT 180 l 1~230V (incl. booster heater) (7) (only for UK)	o
*KHWSU200D*3V3	Domestic hot water tank LT 200 l 1~230V (incl. booster heater) (7) (only for UK)	o
*KHWSU250D*3V3	Domestic hot water tank LT 200 l 1~230V (incl. booster heater) (7) (only for UK)	o
*KHWSU300D*3V3	Domestic hot water tank LT 300 l 1~230V (incl. booster heater) (7) (only for UK)	o
*KHWP300B	Domestic hot water tank 300 l (14)(5)	o
*KHWP500B	Domestic hot water tank 500 l (5)	o
*KHWP300PB	Domestic hot water tank 300 l, with solar support (5)	o
*KHWP500PB	Domestic hot water tank 500 l, with solar support (5)	o
KSRPS4A	Solar kit (11)	o
KBH3X	Booster heater (9) (11)	o
BZKA7V3	Bizone kit	o
*KRTWA	Wired room thermostat	o
*KRTR1	Wireless room thermostat	o
*KRTETS	External temperature sensor option kit (4)	o

Kit availability for *K2CB*C* (2)

Reference	Description	#
KRCS01-1	Remote sensor for indoor (3)	o

Notes

- (1) To be able to use these options, it is required that control box *KCB*C is part of the system.

(a) Domestic hot water (c) Option box

(b) External room thermostat (d) Electricity meter
- (2) To be able to use these options, it is required that option box *K2CB*C* is part of the system.

(a) Control external heat source (bivalent operation).

(b) Output remote ON/OFF signal space heating/cooling

(c) Remote alarm output

(d) External indoor thermistor
- (3) Only 1 remote sensor can be connected: indoor OR outdoor sensor.
- (4) Can only be used in combination with wireless room thermostat EKTR(1).
- (5) Dedicated connection kit available.
- (6) The simplified user interface (EKUCBS) can only be used in combination with a main user interface (EKUCBL1...8).
- (7) Only possible in combination with EKEXPVES
- (8) Only for OCEANIA
- (9) Only for LT application
- (10) Valve kit EKVHPC is mandatory if a heat pump convector is installed on a reversible model (not mandatory for heating only models).
- (11) For the combination with KHWP, refer to the combination table of KHWP.
- (12) It is not possible to combine simplified user interface KRUCBSC and a LAN adapter.
- (13) Data cable for connection with PC.
- (14) If the sytem does not contain a backup heater, the installation of BS1 is required.
- (15) Mandatory option

Remark

Other combinations than mentioned in this combination table are prohibited.