

EABH-D6V

EABH-D9W

EABX-D6V

EABX-D9W

* Electrical meter specification

- Pulse meter type/voltage-free contact for 5 V DC detection by PCB.

- Possible number of pulses

·0.1· pulse/kWh

·1· pulse/kWh

·10· pulse/kWh

·100· pulse/kWh

·1000· pulse/kWh

- Pulse duration

minimum On time: ·40ms·

Minimum OFF time: ·100ms·

- Measurement type (depending on installation)

Single-phase AC meter

Three-phase AC meter

Balanced loads

Three-phase AC meter

Unbalanced loads

* Electrical meter installation guideline

- It is the responsibility of the installer to cover the complete power consumption with electrical meters (combination of estimation and metering is not allowed).

- Required number of electrical meters

Outdoor unit type		EPGA(11/14/16)DAV3					
Indoor unit type		EAB(H/X)16D(A/F)*			EAV(H/X/Z)16S*DA*		
	Backup heater type	6V		9W	6V		9W
	Backup heater power supply	1~ 230V	3~ 230V	3~ 400V	1~ 230V	3~ 230V	3~ 400V
	Backup heater configuration	2 / 4 / 6 kW	6 kW	3 / 6 / 9 kW	2 / 4 / 6 kW	6 kW	3 / 6 / 9 kW
Normal kWh rate power supply							
Electrical meter type	1~	1	-	-	1	-	-
	3~ balanced	-	-	-	-	-	-
	3~ unbalanced	-	1	1	-	1	1
Preferential kWh rate power supply							
Electrical meter type	1~	2	1	1	2	1	1
	3~ balanced	-	-	-	-	-	-
	3~ unbalanced	-	1	1	-	1	1