

E(B-D)LQ011-016CV3_CW1

Kit availability for *(B/D)LQ*C*

Reference	Description	#
*KCB07CAV3	Control box	(1) 0
*KRUCBL1...8C	User interface language group 1...8	(19) 0
*KRUCBSC	Simplified user interface	(7) 0
*KRSCA1	Remote sensor for outdoor	(3) 0
KPCCAB	PC cable kit	(16) 0
BRP069A61	LAN adapter for smartphone control + Smart Grid applications	(17) 0
BRP069A62	LAN adapter for smartphone control	(17) 0

Kit availability for *KCB*C* (1)

Reference	Description	#
*K2CB07CAV3	Option box	(2) 0
*KMBUHC*3V3	Backup heater kit	(8) (10) (11) 0
*KMBUHC*9W1	Backup heater kit	(8) (10) (11) 0
*KMBHBP1	Bypass kit	(9) 0
*KHWCF	Control board (field supply)	(12) 0
FWXV15AVEB	Heat pump convector	(14) 0
FWXV20AVEB	Heat pump convector	(14) 0
*KVKHPC	Heat pump convector valve kit	(14) 0
*KHWS150D*3V3	Domestic hot water tank LT 150 l 1~230V (incl. booster heater)	0
*KHWS180D*3V3	Domestic hot water tank LT 180 l 1~230V (incl. booster heater)	0
*KHWS200D*3V3	Domestic hot water tank LT 200 l 1~230V (incl. booster heater)	0
*KHWS250D*3V3	Domestic hot water tank LT 250 l 1~230V (incl. booster heater)	0
*KHWS300D*3V3	Domestic hot water tank LT 300 l 1~230V (incl. booster heater)	0
*KHWSU150D*3V3	Domestic hot water tank LT 150 l 1~230V (incl. booster heater)	(10) (only for UK) 0
*KHWSU180D*3V3	Domestic hot water tank LT 180 l 1~230V (incl. booster heater)	(10) (only for UK) 0
*KHWSU200D*3V3	Domestic hot water tank LT 200 l 1~230V (incl. booster heater)	(10) (only for UK) 0
*KHWSU250D*3V3	Domestic hot water tank LT 200 l 1~230V (incl. booster heater)	(10) (only for UK) 0
*KHWSU300D*3V3	Domestic hot water tank LT 300 l 1~230V (incl. booster heater)	(10) (only for UK) 0
*KHWP300B	Domestic hot water tank 300 l	(18) (5) 0
*KHWP500B	Domestic hot water tank 500 l	(5) 0
*KHWP300PB	Domestic hot water tank 300 l, with solar support	(5) 0
*KHWP500PB	Domestic hot water tank 500 l, with solar support	(5) 0
KSRPS4	Solar kit	(15) 0
KBH3X	Booster heater	(13) (15) 0
BZKA7V3	Bizone kit	0
*KRTWA	Wired room thermostat	0
*KRTR1	Wireless room thermostat	0
*KRTETS	External temperature sensor option kit	(4) 0

Factory-mounted optional equipment for KMBUHC*

Description	*KMBUH*3V3	#	*KMBUH*9W1 (6)
Backup heater 3kW 1N~230 V	0		0
Backup heater 6kW 1N~230 V			0
Backup heater 6kW 3N~400 V			0

Kit availability for *K2CB*C* (2)

Reference	Description	#
KRCS01-1	Remote sensor for indoor	(3) 0

- NOTES
1. To be able to use these options, it is required that control box *KCB*C is part of the system.

a. Domestic hot water

b. Backup heater

c. External room thermostat

2. To be able to use these options, it is required that option box *K2CB*C* is part of the system.

a. Control external heat source (bivalent operation).

b. Output remote ON/OFF signal space heating/cooling

c. Remote alarm output

d. External indoor thermistor

3. Only 1 remote sensor can be connected: indoor OR outdoor sensor.

4. Can only be used in combination with wireless room thermostat EKTR(1).

5. Dedicated connection kit available.

6. Unified model, the actual backup heater capacity depends on the actual internal upwiring.

7. The simplified user interface (EKUCBS) can only be used in combination with a main user interface (EKUCBL1...8).

8. In these cases, only 1 BUH units can be installed.

9. If condensation is expected, the installation of valve kit EKMBHBP1 is required.

10. Only possible in combination with EKEXPVES

11. The installation of a backup heater kit is required in some operating conditions. For more information, see the operation range drawing.

12. Only for OCEANIA

13. Only for LT application

14. Valve kit EKVHPC is mandatory if a heat pump convector is installed on a reversible model (not mandatory for heating only models).

15. For the combination with KHWP, refer to the combination table of KHWP.

16. Data cable for connection with PC.

17. It is not possible to combine simplified user interface KRUCBSC and a LAN adapter.

18. If the sytem does not contain a backup heater, the installation of BS1 is required.

19. Mandatory option
- REMARK
- Other combinations than mentioned in this combination table are prohibited.
- 3D115218