



**Heat-up times**



	Heat-up time domestic hot water tank until 45°C	
	E(D/B)LQ05C*	E(D/B)LQ07C*
EKHWS*150*	81	73
EKHWS*200*	84	68
EKHWS*300*	122	99



**Heat loss of domestic hot water tank**

(1)

Domestic hot water tank	Heat loss [kWh/24h]	
	EKHWS*	
EKHWS*	150l	1,55
	200l	1,77
	300l	2,19

Notes

(1) According to EN12897.

Notes

1. Time the heat pump requires to heat up the domestic hot water tank from 10°C to the indicated temperature. See the operation range for maximum domestic hot water tank temperature during heat pump only operation.