



Heat-up times ·GQI (1)·





Heat-up time domestic hot water tank until 45°C	
	ERLQ016CA*
EHV*16S18C*	38
EHV*16S26C*	52
	ERLQ016CA* & EHB*16C*
EKHWS*150*	69
EKHWS*200*	55
EKHWS*300*	80





Notes

1. Time the indoor unit (**heat pump only operation**) requires to heat up the domestic hot water tank from 10°C to the indicated temperature.
   See the operation range for maximum domestic hot water tank temperature during heat pump only operation.