

EHBH-CBV

1 Phase C Series
4~8kW Class

Backup heater





Legend

Backup heater only operation
No outdoor unit operation

Operation of outdoor unit possible, but with possible capacity reduction. If the outdoor temperature < -25°C, the outdoor unit will stop. Indoor unit and backup heater operation will continue.

Outdoor unit operation if setpoint ≥ 25°C

Circulation pump

Outdoor unit operation + backup heater operation

Remark

In restricted power supply mode, the outdoor unit, anti-legionella heater and backup heater can only operate seperatly.