


EHSH-E

EHSHB-E

EHSX-E

EHSXB-E

• 1..phase ·D/E· series
·4-8· kW class



Legend

■ Booster heater only operation (if a booster heater is part of the system)

- (1) ·EHSV*·^S·CBV· indoor units only
- (2) Combination of ·EKHWS(P)1*DA*· and ·EHB*D/E(A/F)V*· indoor units
- (3) Combination of ·EKHWS(P)(2/3)*DA*· and ·EHB*D/E(A/F)V*· indoor units

(*)

System operation: the system consists of an outdoor unit and indoor unit, and depending on the system, a booster heater and/or a backup heater.

Remark

In restricted power supply mode (·EKHW*· only), the outdoor unit, booster heater and backup heater can only operate separately.

If the outdoor temperature $< -20^{\circ}\text{C}$, then outdoor unit operation is possible, but with a possible capacity reduction.

If the outdoor temperature $< -25^{\circ}\text{C}$, the outdoor unit will stop.

Indoor unit and backup heater operation will continue.