


-=†Œ- †
- = † = Œ- - †
- = † = Œ- - ‡
- = †Œ- †8

Heat-up times



	Heat-up time domestic hot water tank until 45°C
EHV*04S*18(D/E)(A/J)*	·79· min.
EHV*08S*23(D/E)(A/J)*	·87· min.

Notes

1. Time the indoor unit (**heat pump only operation**) requires to heat up the domestic hot water tank from 10°C to the indicated temperature.

See the operation range for maximum domestic hot water tank temperature during heat pump only operation.