

* Electrical meter specification

- Pulse meter type/voltage-free contact for 5 V DC detection by PCB.
- Possible number of pulses
 - 0.1 pulse/kWh
 - 1 pulse/kWh
 - 10 pulse/kWh
 - 100 pulse/kWh
 - 1000 pulse/kWh
- Pulse duration
 - minimum On time: 40ms
 - Minimum OFF time: 100ms
- Measurement type (depending on installation)
 - Single-phase AC meter
 - Three-phase AC meter
 - Balanced loads
 - Three-phase AC meter
 - Unbalanced loads

* Electrical meter installation guideline

- It is the responsibility of the installer to cover the complete power consumption with electrical meters (combination of estimation and metering is not allowed).
- Required number of electrical meters

Outdoor unit type	*RLQ(04/06/08)*			*R*Q(011/014/016)*V3			*R*Q(011/014/016)*W1							
Indoor unit type	*H(B/V)(H/X)(04/08)C*			*H(B/V)(H/X)(11/16)C*			*H(B/V)(H/X)(11/16)C*							
Backup heater type	3V / 9W	9W	9W	3V / 9W	9W	9W	3V / 9W	9W	9W					
Backup heater power supply	1~ 230V	3~ 400V	3~ 230V	1~ 230V	3~ 400V	3~ 230V	1~ 230V	3~ 400V	3~ 230V					
Backup heater configuration	3 / 6 3 / 6 kW	6 / 9 kW	6 kW	3 / 6 3 / 6 kW	6 / 9 kW	6 kW	3 / 6 kW	6 / 9 kW	6 kW					
Normal kWh rate power supply														
Electrical meter type	1~	1	1	-	-	1	1	-	-	1	-	1	-	-
	3~ balanced	-	1	-	-	-	1	-	-	1	-	1	-	-
	3~ unbalanced	-	-	1	1	-	-	1	1	-	1	-	1	1
Preferential kWh rate power supply														
Electrical meter type	1~	2	1	1	2	1	1	1	1	-	-	-	-	-
	3~ balanced	-	-	-	-	-	-	1	-	1	-	1	-	1
	3~ unbalanced	-	-	1	1	-	1	1	-	-	-	1	-	1