








EHVH-CBV

1 Phase C Series
4~8kW Class

Backup heater



Legend

-  Backup heater only operation
No outdoor unit operation
-  Operation of outdoor unit possible, but with possible capacity reduction. If the outdoor temperature < -25°C, the outdoor unit will stop. Indoor unit and backup heater operation will continue.
-  Outdoor unit operation if setpoint $\geq 25^{\circ}\text{C}$
-  Circulation pump
-  Outdoor unit operation + backup heater operation

Remark

In restricted power supply mode, the outdoor unit, anti-legionella heater and backup heater can only operate separately.