* Electrical meter specification

- Pulse meter type/voltage-free contact for 5 V DC detection by PCB.
- Possible number of pulses
  - 0.1 pulse/kWh
  - 1 pulse/kWh
  - 10 pulse/kWh
  - 100 pulse/kWh
  - 1000 pulse/kWh
- Pulse duration
  - minimum On time: 40ms
  - Minimum OFF time: 100ms
- Measurement type (depending on installation)
  - Single-phase AC meter
  - Three-phase AC meter
    - Balanced loads
  - Three-phase AC meter
    - Unbalanced loads

* Electrical meter installation guideline

- It is the responsibility of the installer to cover the complete power consumption with electrical meters (combination of estimation and metering is not allowed).
- Required number of electrical meters

Outdoor unit type		*RLQ(04/06/08)*				*R*Q(011/014/016)*V3				*R*Q(011/014/016)*W1				
Indoor unit type		*H(B/V)(H/X)(04/08)C*				*H(B/V)(H/X)(11/16)C*				*H(B/V)(H/X)(11/16)C*				
	Backup heater type	3V / 9W	9W		9W	3V / 9W	9W		9W	3V / 9W		9W		9W
	Backup heater power supply	1~ 230V	3~ 400V		3~ 230V	1~ 230V	3~ 400V		3~ 230V	1~ 230V		3~ 400V		3~ 230V
	Backup heater configuration	3 / 6 kW	6 / 9 kW		6 kW	3 / 6 kW	6 / 9 kW		6 kW	3 / 6 kW		6 / 9 kW		6 kW
		Normal kWh rate power supply												
Electrical meter type	1~	1	1	-	-	1	1	-	-	1	-	1	-	-
	3~ balanced	-	1	-	-	-	1	-	-	1	-	1	-	-
	3~ unbalanced	-	-	1	1	-	-	1	1	-	1	-	1	1
		Preferential kWh rate power supply												
Electrical meter type	1~	2	1		1	2	1		1	1		-		-
	3~ balanced	-	-		-	-	-		-	1		1		1
	3~ unbalanced	-	1		1	-	1		1	-		1		1