* Electrical meter specification

- Pulse meter type/voltage-free contact for 5 V DC detection by PCB.
- Possible number of pulses
  - 0.1 pulse/kWh
  - 1 pulse/kWh
  - 10 pulse/kWh
  - 100 pulse/kWh
  - 1000 pulse/kWh
- Pulse duration
  - minimum On time: 40ms
  - Minimum OFF time: 100ms
- Measurement type (depending on installation)
  - Single-phase AC meter
  - Three-phase AC meter
    - Balanced loads
  - Three-phase AC meter
    - Unbalanced loads

* Electrical meter installation guideline

- It is the responsibility of the installer to cover the complete power consumption with electrical meters (combination of estimation and metering is not allowed).
- Required number of electrical meters

Outdoor unit type		*RLQ(04/06/08)*	*R*Q(011/014/016)*V3	*R*Q(011/014/016)*W1	
Indoor unit type		EHVZ(04/08)S18CB3V	EHVZ16S18CB3V	EHVZ16S18CB3V	
	Backup heater type	3V	3V	3V	
	Backup heater power supply	1~ 230V	1~ 230V	1~ 230V	
	Backup heater configuration	3 kW	3 kW	3 kW	
		Normal kWh rate power supply			
Electrical meter type	1~	1	1	1	-
	3~ balanced	-	-	1	-
	3~ unbalanced	-	-	-	1
		Preferential kWh rate power supply			
Electrical meter type	1~	2	2	1	
	3~ unbalanced	-	-	1	