


Heat-up times



	Heat-up time domestic hot water tank until 45°C
ERRA*EA* + ELS(X/H)(B/-)12P30E*	-131- min.
ERRA*EA* + ELS(X/H)(B/-)12P50E*	-197- min.

Notes

1. Time the indoor unit (**heat pump only operation**) requires to heat up the domestic hot water tank from 10°C to the indicated temperature.
 See the operation range for maximum domestic hot water tank temperature during heat pump only operation.

Selection guide for the domestic hot water tank volume

Ve_q 40°C = the amount of water with a temperature of 40°C that can be tapped when the domestic hot water tank is heated to a certain temperature, and the temperature of the cold inlet water is 10°C.

