

Maximum cooling capacity

	Tamb [°C]	20		25		30		35		40		45	
	LWE [°C]	CC [kW]	PI [kW]	CC [kW]	PI [kW]	CC [kW]	PI [kW]	CC [kW]	PI [kW]	CC [kW]	PI [kW]	CC [kW]	PI [kW]
EB(H/L)Q011*6W1	7	11,08	2,79	10,99	3,06	10,62	3,35	10,00	3,69	9,16	4,06	8,14	4,47
	10	11,77	2,82	11,66	3,09	11,27	3,40	10,61	3,74	9,73	4,12	8,65	4,53
	13	12,93	2,85	12,81	3,13	12,38	3,44	11,66	3,79	10,70	4,17	9,39	4,74
	15	13,74	2,87	13,61	3,15	13,15	3,47	12,39	3,82	11,37	4,21	9,73	4,63
	18	15,17	2,90	14,66	3,19	13,87	3,51	12,85	3,87	11,61	4,27	9,85	4,27
	22	16,92	2,94	16,36	3,24	15,49	3,57	14,36	3,94	13,00	4,35	10,32	3,82
EB(H/L)Q014*6W1	7	13,87	3,87	13,75	4,21	13,29	4,61	12,50	5,07	11,08	4,87	9,81	5,36
	10	14,92	3,93	14,79	4,29	14,28	4,70	13,43	5,16	11,92	4,95	10,56	5,44
	13	16,38	3,99	16,23	4,36	15,68	4,78	14,75	5,25	13,09	5,03	10,95	5,52
	15	17,39	4,04	17,23	4,41	16,64	4,84	15,66	5,31	13,91	5,09	11,35	5,39
	18	18,92	4,11	18,28	4,49	17,29	4,92	15,99	5,41	13,99	5,18	11,49	4,98
	22	21,07	4,20	20,37	4,60	19,28	5,04	17,85	5,53	15,65	5,30	12,05	4,45
EB(H/L)Q016*6W1	7	14,52	4,39	14,44	4,79	13,95	5,24	13,10	5,74	11,57	5,48	9,84	5,37
	10	15,65	4,48	15,53	4,89	14,99	5,35	14,07	5,85	12,43	5,58	10,59	5,46
	13	17,19	4,57	17,05	4,99	16,45	5,45	15,44	5,96	13,64	5,68	10,98	5,54
	15	18,26	4,63	18,09	5,06	17,46	5,52	16,39	6,04	14,49	5,75	11,38	5,41
	18	19,87	4,73	19,20	5,16	18,14	5,63	16,73	6,15	14,57	5,85	11,52	5,00
	22	22,14	4,86	21,39	5,30	20,21	5,79	18,66	6,31	16,28	6,00	12,08	4,47

SYMBOLS:

CC Cooling capacity at maximum operating frequency, measured acc. EN14511
 PI Power input, measured acc. EN14511
 LWE Leaving Water Evaporator temperature
 Tamb Ambient temperature; RH = 85%

NOTES:

- For the model with heatertape (*D/B/LQ): when ambient temperature becomes lower than 'X': bottomplate heater power input to be added = 95W
 1) For AA models: 'X' = 4°C
 2) For BA models: 'X' = [F-02] = BPH ON temp (default = 3°C); for more details see installation manual of indoor unit

NOTES

(a) only E(D/B)L*