

*Electrical meter specification

- Pulse meter type / voltage free contact for 5 VDC detection by PCB
- Possible number of pulse:
 - 0.1 pulse/kWh
 - 1 pulse/kWh
 - 10 pulse/kWh
 - 100 pulse/kWh
 - 1000 pulse/kWh
- Pulse duration:
 - Minimum ON time 40ms
 - Minimum OFF time 100ms
- Measurement type (depending on installation):
 - Single phase AC meter
 - Three phase AC meter (balanced loads)
 - Three phase AC meter (unbalanced loads)

*Electrical meter installation guideline

- General: it is the responsibility of the installer to cover the complete power consumption with electrical meters.
- Required number of electrical meters:

Unit type		EGSQH10S18A9W
		Regular kWh rate power supply
Electrical meter type	1~	-
	3~balanced	1
	3~unbalanced	-
		Benefit kWh rate power supply
Electrical meter type	1~	1
	3~balanced	1
	3~unbalanced	-