

EPRA14-18DV7 / EPRA14-18DW7

Installation requirements for ·EPRA*DA*· units

Cascading outdoor units.

The installation layouts with multiple outdoor units shown in ·(1)· (side to side) and ·(2)· (front to back/back to front) are only allowed in combination with wall-mounted indoor units, NOT in combination with floor-standing indoor units.

Legend	Symbols
A, C	Obstacles (walls/baffle plates)
B	Obstacles on the suction side
D	Obstacles on the discharge side
E	Obstacle (roof)
a,b,c,d,e	Minimum service space between the unit and obstacles A, B, C, D and E
e_B	Maximum distance between the unit and the edge of obstacle E, in the direction of obstacle B
e_D	Maximum distance between the unit and the edge of obstacle E, in the direction of obstacle D
Hu	Height of the unit
Hb,Hd	Height of obstacles B and D
⊙	Not allowed



(1)



(2)