

EPRA14-18DV7

EPRA14-18DW7

Datos nominales para los programas de certificación - modo calefacción

Tamb	EWC	LWC	EPRA14DAV3(7)		COP	EPRA16DAV3(7)		COP	EPRA18DAV3(7)		COP	EPRA14DA(B)W1(7)		COP	EPRA16DA(B)W1(7)		COP	EPRA18DA(B)W1(7)		Utilizado para:
			HC	TC		HC	TC		HC	TC		HC	TC		HC	TC		HC	TC	
7/6	30	35	5,69		4,67	9,00		5,00	9,00		5,00	5,90		4,79	9,00		5,00	9,00		5,00
2/1	(30)	35	7,88		4,31	7,88		4,31	7,88		4,31	7,52		4,09	7,52		4,09	7,52		4,09
-7/8	(30)	35	10,81		3,27	11,78		3,21	12,78		3,15	10,18		3,21	11,40		3,13	12,67		3,05
7/6	40	45	7,90		3,42	7,90		3,42	7,90		3,42	7,90		3,42	7,90		3,42	7,90		3,42
7/6	47	55	7,24		3,01	7,24		3,01	7,24		3,01	7,24		2,93	7,24		2,93	7,24		2,93
-7/8	47	55	9,81		2,25	9,81		2,25	9,81		2,25	9,21		2,22	9,21		2,22	9,21		2,22

Datos nominales para los programas de certificación - modo refrigeración

Capacidad nominal de refrigeración

Tamb	EWE	LWE	EPRA14DAV3(7)		EER	EPRA16DAV3(7)		EER	EPRA18DAV3(7)		EER	EPRA14DA(B)W1(7)		EER	EPRA16DA(B)W1(7)		EER	EPRA18DA(B)W1(7)		Utilizado para:
			CC	TC		CC	TC		CC	TC		CC	TC		CC	TC		CC	TC	
35	23	18	10,55		4,13	11,51		4,11	12,46		4,09	10,55		4,13	11,51		4,11	12,46		4,09
35	12	7	6,90		2,7	7,88		2,69	8,86		2,68	6,90		2,7	7,88		2,69	8,86		2,68

Datos estacionales - refrigeración

LWE 7°C

Temperatura baja
Aplicación

Pdes	SEER	η _{h,c}	QCE	EPRA14DAV3(7)		EPRA16DAV3(7)		EPRA18DAV3(7)		EPRA14DA(B)W1(7)		EPRA16DA(B)W1(7)		EPRA18DA(B)W1(7)	
				[kW]		[kW]		[kW]		[kW]		[kW]		[kW]	
-1				6,9		7,9		8,8		6,9		7,9		8,8	
SEER				3,99		4,08		4,17		3,87		3,98		4,07	
η _{h,c}				157		160		164		152		156		160	
QCE				1038		1158		1266		1069		1188		1296	

Datos nominales para los programas de certificación - rendimiento de agua caliente sanitaria

Interior exterior	ETV*16S18D/BID* ^a		ETV*16S23D/EA* ^a		ETSX/M16/16P30DA		ETSX/M16P50DA		ETSX/H16/16P50DA		ETSX/H16/16P30E* ^a		ETSX/H16/16P50E* ^a		Utilizado para:
	EPRA*DAV3(7)	EPRA*DA(B)W1(7)	EPRA*DAV3(7)	EPRA*DA(B)W1(7)	EPRA*DAV3(7)	EPRA*DA(B)W1(7)	EPRA*DAV3(7)	EPRA*DA(B)W1(7)	EPRA*DAV3(7)	EPRA*DA(B)W1(7)	EPRA*DAV3(7)	EPRA*DA(B)W1(7)	EPRA*DAV3(7)	EPRA*DA(B)W1(7)	
Aplicación	Clima medio														Keymark
Volumen del depósito de agua caliente sanitaria [l]	180		230		294		477		294		477		294		
Patrón de suministro	L		XL		L		XL		L		XL		L		
Tempo de calentamiento (h:mm:ss)	01:06:36		01:19:36		01:25:00		01:41:00		02:18:00		02:11:00		01:25:18		
ρ _{des}	52,5		52,5		47,0		47,0		51,0		47,0		51,0		
P _{des}	34,2		42,9		49,2		58,5		49,0		57,1		57,6		
V _{des}	240,0		298		149		237,2		215,7		211,0		193		
η _{des}	109,5		105,7		108,3		106,6		101		111		108		
COP _{des}	2,62		2,51		2,55		2,38		2,67		2,58		2,85		