


ERGA-EV
ERGA-EVH
ERGA-EVH7



Legend

- Booster heater only operation (if a booster heater is part of the system)
- (1) ·EHVH*S*CBV· indoor units only
- (2) Combination of ·EKHWS(P)1*DA*· and ·EHB*D/E(A/F)V*· indoor units
- (3) Combination of ·EKHWS(P)(2/3)*DA*· and ·EHB*D/E(A/F)V*· indoor units

(*) System operation: the system consists of an outdoor unit and indoor unit, and depending on the system, a booster heater and/or a backup heater.

Remark

- In restricted power supply mode (·EKHW· only), the outdoor unit, booster heater and backup heater can only operate separately.
- If the outdoor temperature ·<-20·°C, then outdoor unit operation is possible, but with a possible capacity reduction.
- If the outdoor temperature < -25°C, the outdoor unit will stop.
- Indoor unit and backup heater operation will continue.