

EBBH-D6V

EBBH-D9W

EBBX-D6V

EBBX-D9W

* Electrical meter specification

- Pulse meter type/voltage-free contact for 5 V DC detection by PCB.
- Possible number of pulses
 - 0.1· pulse/kWh
 - 1· pulse/kWh
 - 10· pulse/kWh
 - 100· pulse/kWh
 - 1000· pulse/kWh
- Pulse duration
 - minimum On time: ·40ms·
 - Minimum OFF time: ·100ms·
- Measurement type (depending on installation)
 - Single-phase AC meter
 - Three-phase AC meter
 - Balanced loads
 - Three-phase AC meter
 - Unbalanced loads

* Electrical meter installation guideline

- It is the responsibility of the installer to cover the complete power consumption with electrical meters (combination of estimation and metering is not allowed).
- Required number of electrical meters

Outdoor unit type		ERLA(11/14/16)D(A/2)(V3/W1)(7)							
Indoor unit type		EBB(H/X)(11/16)D(F/J)*			EBV(H/X/Z)(11/16)S(18/23)DJ*			EBVH16SU23DJ6V	
Backup heater type		6V		9W	6V		9W	6V	
Backup heater power supply		1~ 230V	3~ 230V	3~ 400V	1~ 230V	3~ 230V	3~ 400V	1~ 230V	3~ 230V
Backup heater configuration		2 / 4 / 6 kW	6 kW	3 / 6 / 9 kW	2 / 4 / 6 kW	6 kW	3 / 6 / 9 kW	2 / 4 / 6 kW	6 kW
Normal kWh rate power supply									
Electrical meter type	1~	1	-	-	1	-	-	1	-
	3~ balanced	-	-	-	-	-	-	-	-
	3~ unbalanced	-	1	1	-	1	1	-	1
Preferential kWh rate power supply									
Electrical meter type	1~	2	1	1	2	1	1	2	1
	3~ balanced	-	-	-	-	-	-	-	-
	3~ unbalanced	-	1	1	-	1	1	-	1