

* Electrical meter specification

- Pulse meter type/voltage-free contact for 5 V DC detection by PCB.
 - Possible number of pulses
 - 0.1· pulse/kWh
 - 1· pulse/kWh
 - 10· pulse/kWh
 - 100· pulse/kWh
 - 1000· pulse/kWh
 - Pulse duration
 - minimum On time: ·40ms·
 - Minimum OFF time: ·100ms·
 - Measurement type (depending on installation)
 - Single-phase AC meter
 - Three-phase AC meter
- Balanced loads
- Unbalanced loads

* Electrical meter installation guideline

- It is the responsibility of the installer to cover the complete power consumption with electrical meters (combination of estimation and metering is not allowed).
- Required number of electrical meters

Outdoor unit type		EPRA(14/16/18)D*		
Indoor unit type		ETS*16*EF*		
	Backup heater type (optional)	EKECBU*3V	EKECBU*6V	EKECBU*9W
	Backup heater power supply	1~ 230V	1~ 230V	3~ 400V
	Backup heater configuration	1/2/3 kW	2 / 4 / 6 kW	3 / 6 / 9 kW
Normal kWh rate power supply				
Electrical meter type	1~	1	1	-
	3~ balanced	-	-	-
	3~ unbalanced	-	-	1
Preferential kWh rate power supply				
Electrical meter type	1~	2	2	1
	3~ balanced	-	-	-
	3~ unbalanced	-	-	1