


Heat-up time



Model name	Heat-up time domestic hot water tank until 45°C
EPSK(06/08/10)AR* + EPVX10S*18AJ*	·73· min.
EPSK(06/08/10)AR* + EPVX10S*23AJ*	·97· min.

Notes

1. Time the indoor unit (heat pump only operation) requires to heat up the domestic hot water tank from 10°C to the indicated temperature.
See the operation range for maximum domestic hot water tank temperature during heat pump only operation.