


Selection guide for the domestic hot water tank volume

Ve_q 40°C = the amount of water with a temperature of 40°C that can be tapped when the domestic hot water tank is heated to a certain temperature, and the temperature of the cold inlet water is 10°C.



If a higher daily Ve_q 40°C is required, then additional heat-up cycles are required within 24 hours.

See the operation manual for more information.