

EPSK06-10AV3

EPSK08-10AW1

EPSK12-14AW1

Datos nominales para los programas de certificación - modo calefacción

Medición de acuerdo con UNI/TS 11300

Condición	TAMB [°C]	LWC [°C]	PLR [%]	EPSK06ARV3		EPSK08ARV3		EPSK08ARW1		EPSK10ARV3		EPSK10ARW1		EPSK12ARW1		EPSK14ARW1	
				HC [kW]	COP	HC [kW]	COP	HC [kW]	COP	HC [kW]	COP	HC [kW]	COP	HC [kW]	COP	HC [kW]	COP
A	-7/-8	34	100	6.22	3.45	7.94	3.22	7.94	3.22	8.51	2.82	8.51	2.82	10.44	3.12	13.74	2.80
B	2/1	30	100	4.88	3.96	5.94	3.62	5.94	3.62	6.94	3.47	6.94	3.47	9.50	4.36	11.09	3.76
C	7/6	27	100	5.91	6.48	7.55	5.82	7.55	5.82	9.64	5.39	9.64	5.39	10.62	5.87	10.73	4.79
D	12/11	24	100	6.96	8.58	6.96	8.58	6.96	8.58	8.36	7.80	8.36	7.80	10.96	9.09	13.50	8.26
A	-7/-8	52	100	6.47	2.60	8.18	2.46	8.18	2.46	9.76	2.38	9.76	2.38	12.22	2.49	13.87	2.19
B	2/1	42	100	4.44	2.99	5.89	3.00	5.89	3.00	7.25	3.00	7.25	3.00	9.44	3.43	10.93	3.19
C	7/6	36	100	5.95	5.22	7.65	4.90	7.65	4.90	9.81	4.68	9.81	4.68	12.28	5.34	10.52	4.24
D	12/11	30	100	4.87	7.53	6.30	7.14	6.30	7.14	8.25	6.85	8.25	6.85	10.41	7.82	12.91	6.96

Datos nominales para los programas de certificación - modo refrigeración

Medición de acuerdo con UNI/TS 11300

Condición	TAMB [°C]	LWE [°C]	PLR [%]	EPSK06ARV3		EPSK08ARV3		EPSK08ARW1		EPSK10ARV3		EPSK10ARW1		EPSK12ARW1		EPSK14ARW1	
				CC [kW]	EER	CC [kW]	EER	CC [kW]	EER	CC [kW]	EER	CC [kW]	EER	CC [kW]	EER	CC [kW]	EER
A	35	18	100	8.61	5.53	9.67	5.10	9.67	5.10	10.78	4.79	10.78	4.79	11.97	4.24	14.50	3.72
B	30	18	75	6.24	7.15	7.64	6.83	7.64	6.83	8.46	6.70	8.46	6.70	10.00	5.45	12.49	4.90
C	25	18	50	4.45	9.86	4.79	9.74	4.79	9.74	5.67	9.50	5.67	9.50	6.71	7.08	8.60	6.14
D	20	18	25	3.37	12.25	3.37	12.25	3.37	12.25	3.37	12.25	3.37	12.25	9.59	7.82	9.59	7.82
A	35	7	100	6.00	3.87	6.91	3.76	6.91	3.76	7.84	3.62	7.84	3.62	9.37	3.55	11.30	3.28
B	30	7	75	4.39	4.96	4.97	4.77	4.97	4.77	5.66	4.62	5.66	4.62	7.27	3.99	9.13	3.68
C	25	7	50	2.93	6.01	3.39	5.97	3.39	5.97	4.11	5.93	4.11	5.93	4.93	4.92	6.34	4.57
D	20	7	25	6.54	5.90	6.54	5.90	6.54	5.90	6.54	5.90	6.54	5.90	7.03	5.46	7.07	5.50