



- 1 Height of the walls in case of patterns 1 and 2:

Front: 1500

suction side: 500mm

Side: Height unrestricted.

The installation space shown on this drawing is based on cooling operation at 32°C (outdoor temperature).

If the design outdoor air temperature exceeds 32°C, provide a broader suction space than showing on the drawing.

- 2 If the walls are higher than mentioned above, then additional space is needed.

Suction side: service space +  $h2/2$

Front side: service space +  $h1/2$

See figure 1

- 3 When installing the units, select the pattern that best fits the available space.

Always keep in mind to leave sufficient space for a person to pass between unit and wall and for the air to circulate freely.

If more units are to be installed than are catered for in the above patterns, your layout should take into account of the possibility of short circuits.

- 4 Provide sufficient space at the front to connect refrigerant piping (comfortably).

