



**NOTES**

1. Range for humidity (Air-conditioner(cooling)) ••• RH80% or below  
Range for humidity (Refrigeration) ••• RH95% or below
2. "Range for continuous operation" shows possible range of continuous operation.
3. "Range for pull down operation" shows possible range of short-time operation.
  - Do not select the model in the range for pull down operation.
  - To be more than 3°C/hour that the temperature of indoor unit drops, do not open the door and do not enter the goods in pull down operation as possible. (Refrigeration)