


**Outdoor DB Temperature** [°C]: Outdoor air temperature that strikes the condensing coil (dry bulb). **Indoor DB Temperature** [°C]: Indoor air temperature that strikes the evaporating coil (dry bulb).



**Outdoor DB Temperature** [°C]: Outdoor air temperature that strikes the evaporating coil (dry bulb). **Indoor DB Temperature** [°C]: Indoor air temperature that strikes the condensing coil (dry bulb).

