
FHQ35C



Note:

- Location of unit's name plate: bottom of fan housing inside the suction grille.
 In case of using infrared remote controller, this position will be a signal receiver. Refer to the drawing of infrared remote controller in detail.
 Please do not place the thing been damp and troubled under an indoor unit. When the case where humidity is 80% or more, and the drain outlet are choked up and the air filter are dirty, dew may fall.