
## FVQ100C



## NOTES

1	Overall (	CIR)		
	Scale	230V		
		high	middle	low
	A	50	47	44
	C	55	52	50

230V				
high	middle	low		
62	59	56		

(B,G,N is already rectified)

- 2 Measuring place: Anechoic chamber
- 3 Operation noise differs with operation and ambient conditions.
- 4 Operating conditions: Power source: 230V 50Hz
- 5 Cooling: Return air temperature: 27°C DB, 19°C WB
- Outdoor temperature: 35°C DB, 24°C WB
- 6 Heating: Return air temperature: 20°C DB, 15°C WB Outdoor temperature: 7°C DB, 6°C WB O——O 230V
- 7 Location of microphone Microphone 1 m