



## NOTES

1 Overall (dB)

Scale	high	middle	low
A	44	41	37
C	47	44	40

(R.G.N is already rectified)

2 Measuring place: Anechoic chamber

3 Operation noise differs with operation and ambient conditions.

4 Operating conditions: Power source: 220~240V 50Hz/220V 60Hz

5 Cooling: Return air temperature: 27°CDB, 19°CWB

Outdoor temperature: 35°CDB, 24°CWB

6 Heating: Return air temperature: 20°CDB, 15°CWB

Outdoor temperature: 7°CDB, 6°CWB

7 Location of microphone

