



Cooling



- ① Operation range
- ② Pull-down operation range
- ③ Warm-up operation range

Heating



Notes

1. Depending on operation and installation conditions, the indoor unit can change over to freeze-up operation (indoor de-icing).
2. To reduce the freeze-up operation (indoor de-icing) frequency, it is recommended to install the outdoor unit in a location not exposed to wind.
3. If the unit is selected to operate at ambient temperature < -5°C for -3- days or more, with relative humidity of 100%, it is required to install the optional bottom plate heater.