

## Notes

1. The ·RLA· is based on the following conditions.  
Indoor temperature ·27·°C DB / ·19·°C WB  
Outdoor temperature ·35·°C DB
2. Select the wire size according to the MCA.
3. The maximum allowable voltage that is unbalanced between phases is ·2·%.
4. Use a circuit breaker instead of a fuse.

## Symbols

①	Hz	OFM	Outdoor fan motor
②	Voltage	IFM	Indoor fan motor
③	Voltage range	FLA	Full Load Ampere (A)
MCA	Minimum Circuit Ampere [A]	kW	Fan motor rated output [kW]
MFA	Maximum Fuse Ampere [A]	RHz	Rated operating frequency [Hz]
RLA	Rated load amps [A]	COMP	Compressor