




RZQSG-L(8)Y1



Notes:

- 1 Depending on operation and installation conditions, the outdoor unit can change over to defrost operation (anti freeze-up).
- 2 To reduce the defrost operation (anti freeze-up) frequency it is recommended to install the outdoor unit in a location not exposed to wind.
- 3 In case of high humidity conditions (>92%) in this  operation area, an RZQG model should be used instead of an RZQSG model. This to avoid freeze-up of the outdoor unit.