

5MXM90A9

Cooling ·230V 50Hz·

Outdoor unit	Indoor unit	Cooling capacity [kW]					Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room ·A·	Room ·B·	Room ·C·	Room ·D·	Room ·E·	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
5MXM90M2V1B 5MXM90N2V1B 5MXM90N2V1B9 5MXM90A2V1B 5MXM90A2V1B9 5MXM90A2V1B8	1.5+1.5+3.5+4.2	1.26	1.26	2.94	3.53	-	2.95	9.00	9.39	0.56	2.41	2.61	2.57	11.10	12.00	95
	1.5+1.5+3.5+5.0	1.17	1.17	2.74	3.91	-	3.07	9.00	9.74	0.59	2.36	2.75	2.69	10.80	12.70	95
	1.5+1.5+3.5+6.0	1.08	1.08	2.52	4.32	-	3.21	9.00	10.18	0.59	2.36	3.02	2.69	10.80	13.90	95
	1.5+1.5+3.5+7.1	0.99	0.99	2.32	4.70	-	3.42	9.00	10.20	0.56	2.35	3.02	2.70	10.80	13.90	95
	1.5+1.5+4.2+4.2	1.18	1.18	3.32	3.32	-	3.05	9.00	9.61	0.59	2.41	2.74	2.69	11.10	12.60	95
	1.5+1.5+4.2+5.0	1.11	1.11	3.10	3.69	-	3.17	9.00	9.75	0.59	2.36	2.75	2.69	10.80	12.70	95
	1.5+1.5+4.2+6.0	1.02	1.02	2.86	4.09	-	3.41	9.00	10.19	0.56	2.35	3.02	2.70	10.80	13.90	95
	1.5+1.5+4.2+7.1	0.94	0.94	2.64	4.47	-	3.60	9.00	10.20	0.60	2.35	3.02	2.80	10.80	13.90	95
	1.5+1.5+5.0+5.0	1.04	1.04	3.46	3.46	-	3.43	9.00	9.97	0.56	2.31	2.83	2.70	10.60	13.00	95
	1.5+1.5+5.0+6.0	0.96	0.96	3.21	3.86	-	3.44	9.00	10.42	0.56	2.31	3.10	2.70	10.60	14.20	95
	1.5+1.5+5.0+7.1	0.89	0.89	2.98	4.23	-	3.62	9.00	10.73	0.60	2.30	3.30	2.80	10.60	15.20	95
	1.5+1.5+6.0+6.0	0.90	0.90	3.60	3.60	-	3.62	9.00	10.74	0.60	2.30	3.31	2.80	10.60	15.20	95
	1.5+2.0+2.0+2.0	1.50	2.00	2.00	2.00	-	2.48	7.50	7.89	0.47	1.74	1.91	2.15	8.00	8.80	95
	1.5+2.0+2.0+2.5	1.41	1.88	1.88	2.34	-	2.55	7.50	8.15	0.50	1.74	2.02	2.27	8.00	9.30	95
	1.5+2.0+2.0+3.5	1.33	1.78	1.78	3.11	-	2.70	8.00	8.78	0.53	1.95	2.30	2.44	9.00	10.60	95
	1.5+2.0+2.0+4.2	1.31	1.75	1.75	3.68	-	2.80	8.50	9.12	0.53	2.18	2.49	2.44	10.00	11.40	95
	1.5+2.0+2.0+5.0	1.24	1.66	1.66	4.14	-	2.92	8.70	9.48	0.56	2.23	2.62	2.57	10.30	12.00	95
	1.5+2.0+2.0+6.0	1.17	1.57	1.57	4.70	-	3.07	9.00	9.94	0.56	2.36	2.88	2.57	10.90	13.20	95
	1.5+2.0+2.0+7.1	1.07	1.43	1.43	5.07	-	3.23	9.00	10.26	0.60	2.36	3.08	2.74	10.90	14.20	95
	1.5+2.0+2.5+2.5	1.41	1.88	2.35	2.35	-	2.63	8.00	8.52	0.50	1.95	2.19	2.27	9.00	10.10	95
	1.5+2.0+2.5+3.5	1.26	1.68	2.11	2.95	-	2.77	8.00	9.02	0.53	1.95	2.42	2.44	9.00	11.20	95
	1.5+2.0+2.5+4.2	1.25	1.67	2.08	3.50	-	2.88	8.50	9.36	0.56	2.17	2.61	2.57	10.00	12.00	95
	1.5+2.0+2.5+5.0	1.23	1.64	2.05	4.09	-	2.99	9.00	9.49	0.56	2.36	2.62	2.57	10.90	12.10	95
	1.5+2.0+2.5+6.0	1.13	1.50	1.88	4.50	-	3.14	9.00	10.05	0.59	2.36	2.95	2.69	10.90	13.60	95
	1.5+2.0+2.5+7.1	1.03	1.37	1.72	4.88	-	3.41	9.00	10.16	0.56	2.36	3.01	2.70	10.80	13.90	95
	1.5+2.0+3.5+3.5	1.24	1.66	2.90	2.90	-	2.92	8.70	9.38	0.56	2.28	2.61	2.57	10.50	12.00	95
	1.5+2.0+3.5+4.2	1.21	1.61	2.81	3.38	-	3.02	9.00	9.60	0.56	2.41	2.74	2.57	11.10	12.60	95
	1.5+2.0+3.5+5.0	1.13	1.50	2.63	3.75	-	3.14	9.00	9.74	0.59	2.36	2.75	2.69	10.80	12.70	95
	1.5+2.0+3.5+6.0	1.04	1.38	2.42	4.15	-	3.41	9.00	10.18	0.56	2.36	3.02	2.70	10.80	13.90	95
	1.5+2.0+3.5+7.1	0.96	1.28	2.23	4.53	-	3.59	9.00	10.20	0.60	2.35	3.02	2.80	10.80	13.90	95
	1.5+2.0+4.2+4.2	1.13	1.51	3.18	3.18	-	3.13	9.00	9.61	0.59	2.41	2.74	2.69	11.10	12.60	95
	1.5+2.0+4.2+5.0	1.06	1.42	2.98	3.54	-	3.41	9.00	9.75	0.56	2.36	2.75	2.70	10.80	12.70	95
	1.5+2.0+4.2+6.0	0.99	1.31	2.76	3.94	-	3.41	9.00	10.19	0.56	2.35	3.02	2.70	10.80	13.90	95
	1.5+2.0+4.2+7.1	0.91	1.22	2.55	4.32	-	3.60	9.00	10.69	0.60	2.35	3.36	2.80	10.80	15.90	95
	1.5+2.0+5.0+5.0	1.00	1.33	3.33	3.33	-	3.43	9.00	9.97	0.56	2.31	2.83	2.70	10.60	13.00	95
	1.5+2.0+5.0+6.0	0.93	1.24	3.10	3.72	-	3.62	9.00	10.42	0.60	2.31	3.10	2.80	10.60	14.20	95
	1.5+2.0+5.0+7.1	0.87	1.15	2.88	4.10	-	3.80	9.00	10.73	0.63	2.30	3.30	3.00	10.60	15.20	95
	1.5+2.0+6.0+6.0	0.87	1.16	3.48	3.48	-	3.80	9.00	10.74	0.63	2.30	3.31	3.00	10.60	15.20	95
	1.5+2.5+2.5+2.5	1.33	2.22	2.22	2.22	-	2.70	8.00	8.77	0.53	1.95	2.30	2.44	9.00	10.60	95
	1.5+2.5+2.5+3.5	1.28	2.13	2.13	2.98	-	2.85	8.50	9.25	0.53	2.17	2.55	2.44	10.00	11.70	95
	1.5+2.5+2.5+4.2	1.26	2.10	2.10	3.53	-	2.95	9.00	9.37	0.56	2.42	2.61	2.57	11.10	12.00	95
	1.5+2.5+2.5+5.0	1.17	1.96	1.96	3.91	-	3.07	9.00	9.72	0.59	2.36	2.75	2.69	10.90	12.60	95
	1.5+2.5+2.5+6.0	1.08	1.80	1.80	4.32	-	3.21	9.00	10.16	0.59	2.36	3.01	2.69	10.80	13.90	95
	1.5+2.5+2.5+7.1	0.99	1.65	1.65	4.70	-	3.41	9.00	10.18	0.56	2.36	3.01	2.70	10.80	13.90	95
	1.5+2.5+3.5+3.5	1.23	2.05	2.86	2.86	-	2.99	9.00	9.39	0.56	2.41	2.61	2.57	11.10	12.00	95
	1.5+2.5+3.5+4.2	1.15	1.92	2.69	3.23	-	3.10	9.00	9.51	0.59	2.41	2.68	2.69	11.10	12.30	95
	1.5+2.5+3.5+5.0	1.08	1.80	2.52	3.60	-	3.21	9.00	9.75	0.59	2.36	2.75	2.69	10.80	12.70	95
	1.5+2.5+3.5+6.0	1.00	1.67	2.33	4.00	-	3.41	9.00	10.19	0.56	2.35	3.02	2.70	10.80	13.90	95
1.5+2.5+3.5+7.1	0.92	1.54	2.16	4.38	-	3.60	9.00	10.21	0.60	2.35	3.02	2.80	10.80	13.90	95	
1.5+2.5+4.2+4.2	1.09	1.81	3.05	3.05	-	3.20	9.00	9.62	0.59	2.41	2.74	2.69	11.10	12.60	95	
1.5+2.5+4.2+5.0	1.02	1.70	2.86	3.41	-	3.41	9.00	9.76	0.56	2.36	2.75	2.70	10.80	12.70	95	
1.5+2.5+4.2+6.0	0.95	1.58	2.66	3.80	-	3.60	9.00	10.20	0.60	2.35	3.02	2.80	10.80	13.90	95	
1.5+2.5+4.2+7.1	0.88	1.47	2.47	4.18	-	3.78	9.00	10.71	0.63	2.35	3.36	3.00	10.80	15.50	95	
1.5+2.5+5.0+5.0	0.96	1.61	3.21	3.21	-	3.42	9.00	9.53	0.59	2.31	2.57	2.69	10.60	11.80	95	
1.5+2.5+5.0+6.0	0.90	1.50	3.00	3.60	-	3.60	9.00	9.78	0.56	2.30	2.70	2.70	10.60	12.40	95	
1.5+3.5+3.5+3.5	1.13	2.63	2.63	2.63	-	3.14	9.00	9.53	0.59	2.41	2.68	2.69	11.10	12.30	95	
1.5+3.5+3.5+4.2	1.06	2.48	2.48	2.98	-	3.39	9.00	9.54	0.56	2.40	2.68	2.70	11.10	12.30	95	
1.5+3.5+3.5+5.0	1.00	2.33	2.33	3.33	-	3.42	9.00	9.78	0.56	2.35	2.75	2.70	10.80	12.70	95	
1.5+3.5+3.5+6.0	0.93	2.17	2.17	3.72	-	3.60	9.00	10.22	0.60	2.35	3.02	2.80	10.80	13.90	95	
1.5+3.5+3.5+7.1	0.87	2.02	2.02	4.10	-	3.78	9.00	10.73	0.63	2.32	3.37	3.00	10.70	15.50	95	
1.5+3.5+4.2+4.2	1.01	2.35	2.82	2.82	-	3.39	9.00	9.55	0.56	2.40	2.68	2.70	11.10	12.30	95	
1.5+3.5+4.2+5.0	0.95	2.22	2.66	3.17	-	3.60	9.00	9.79	0.60	2.35	2.75	2.80	10.80	12.70	95	
1.5+3.5+4.2+6.0	0.89	2.07	2.49	3.55	-	3.78	9.00	10.73	0.63	2.32	3.37	3.00	10.70	15.50	95	
1.5+3.5+5.0+5.0	0.90	2.10	3.00	3.00	-	3.62	9.00	10.53	0.60	2.30	3.17	2.80	10.60	14.60	95	
1.5+4.2+4.2+4.2	0.96	2.68	2.68	2.68	-	3.57	9.00	9.56	0.60	2.40	2.68	2.80	11.00	12.40	95	
1.5+4.2+4.2+5.0	0.91	2.54	2.54	3.02	-	3.60	9.00	10.32	0.60	2.35	3.09	2.80	10.80	14.20	95	
2.0+2.0+2.0+2.0	1.88	1.88	1.88	1.88	-	2.55	7.50	8.14	0.50	1.74	2.02	2.27	8.00	9.30	95	
2.0+2.0+2.0+2.5	1.88	1.88	1.88	2.35	-	2.63	8.00	8.51	0.50	1.95	2.19	2.27	9.00	10.10	95	
2.0+2.0+2.0+3.5	1.68	1.68	1.68	2.95	-	2.77	8.00	9.00	0.53	1.95	2.42	2.44	9.00	11.20	95	
2.0+2.0+2.0+4.2	1.67	1.67	1.67	3.50	-	2.88	8.50	9.34	0.56	2.18	2.61	2.57	10.00	12.00	95	
2.0+2.0+2.0+5.0	1.64	1.64	1.64	4.09	-	2.99	9.00	9.59	0.56	2.37	2.68	2.57	10.90	12.40	95	
2.0+2.0+2.0+6.0	1.50	1.50	1.50	4.50	-	3.14	9.00	10.04	0.60	2.36	2.95	2.74	10.90	13.60	95	
2.0+2.0+2.0+7.1	1.37	1.37	1.37	4.88	-	3.41	9.00	10.26	0.56	2.36	3.08	2.70	10.90	14.20	95	
2.0+2.0+2.5+2.5	1.73	1.73	2.17	2.17	-	2.70	7.80	8.75	0.53	1.88	2.30	2.44	8.70	10.60	95	
2.0+2.0+2.5+3.5	1.70	1.70	2.13	2.98	-	2.85	8.50	9.24	0.53	2.18	2.55	2.44	10.00	11.70	95	
2.0+2.0+2.5+4.2	1.68	1.68	2.10	3.53	-	2.95	9.00	9.36	0.56	2.42	2.61	2.57	11.10	12.00	95	
2.0+2.0+2.5+5.0	1.57	1.57	1.96	3.91	-	3.07	9.0									