

5MXM90A9

Cooling ·230V 50Hz·

Outdoor unit	Indoor unit	Cooling capacity [kW]					Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room ·A·	Room ·B·	Room ·C·	Room ·D·	Room ·E·	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
5MXM90M2V1B 5MXM90N2V1B 5MXM90N2V1B9 5MXM90A2V1B 5MXM90A2V1B9 5MXM90A2V1B8	1.5+1.5+1.5+4.2+5.0	0.99	0.99	0.99	2.76	3.28	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95
	1.5+1.5+1.5+4.2+6.0	0.92	0.92	0.92	2.57	3.67	3.67	9.00	10.62	0.59	2.25	3.12	2.80	10.30	14.30	95
	1.5+1.5+1.5+5.0+5.0	0.93	0.93	0.93	3.10	3.10	3.69	9.00	10.55	0.59	2.21	3.05	2.80	10.20	14.00	95
	1.5+1.5+1.5+5.0+6.0	0.87	0.87	0.87	2.90	3.48	3.69	9.00	10.77	0.59	2.21	3.19	2.80	10.20	14.60	95
	1.5+1.5+2.0+2.0+2.0	1.30	1.30	1.73	1.73	1.73	2.70	7.80	8.74	0.51	1.76	2.15	2.32	8.10	9.90	95
	1.5+1.5+2.0+2.0+2.5	1.26	1.26	1.68	1.68	2.11	2.77	8.00	9.00	0.53	1.85	2.27	2.44	8.50	10.40	95
	1.5+1.5+2.0+2.0+3.5	1.24	1.24	1.66	1.66	2.90	2.92	8.70	9.51	0.53	2.13	2.51	2.44	9.80	11.60	95
	1.5+1.5+2.0+2.0+4.2	1.21	1.21	1.61	1.61	3.38	3.02	9.00	9.74	0.56	2.26	2.64	2.57	10.40	12.20	95
	1.5+1.5+2.0+2.0+5.0	1.13	1.13	1.50	1.50	3.75	3.14	9.00	10.04	0.56	2.25	2.78	2.57	10.40	12.80	95
	1.5+1.5+2.0+2.0+6.0	1.04	1.04	1.38	1.38	4.15	3.29	9.00	10.39	0.60	2.25	2.98	2.74	10.30	13.70	95
	1.5+1.5+2.0+2.0+7.1	0.96	0.96	1.28	1.28	4.53	3.48	9.00	10.61	0.56	2.25	3.11	2.60	10.30	14.30	95
	1.5+1.5+2.0+2.5+2.5	1.28	1.28	1.70	2.13	2.13	2.85	8.50	9.25	0.53	2.06	2.39	2.44	9.50	11.00	95
	1.5+1.5+2.0+2.5+3.5	1.23	1.23	1.64	2.05	2.86	2.99	9.00	9.75	0.56	2.26	2.64	2.57	10.40	12.20	95
	1.5+1.5+2.0+2.5+4.2	1.15	1.15	1.54	1.92	3.23	3.10	9.00	9.98	0.56	2.26	2.77	2.57	10.40	12.70	95
	1.5+1.5+2.0+2.5+5.0	1.08	1.08	1.44	1.80	3.60	3.21	9.00	10.16	0.60	2.25	2.84	2.74	10.40	13.10	95
	1.5+1.5+2.0+2.5+6.0	1.00	1.00	1.33	1.67	4.00	3.48	9.00	10.50	0.56	2.25	3.04	2.60	10.30	14.00	95
	1.5+1.5+2.0+2.5+7.1	0.92	0.92	1.23	1.54	4.38	3.67	9.00	10.61	0.59	2.25	3.11	2.80	10.30	14.30	95
	1.5+1.5+2.0+3.5+3.5	1.13	1.13	1.50	2.63	2.63	3.14	9.00	10.10	0.56	2.26	2.84	2.57	10.40	13.00	95
	1.5+1.5+2.0+3.5+4.2	1.06	1.06	1.42	2.48	2.98	3.24	9.00	10.22	0.60	2.26	2.90	2.74	10.40	13.40	95
	1.5+1.5+2.0+3.5+5.0	1.00	1.00	1.33	2.33	3.33	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95
	1.5+1.5+2.0+3.5+6.0	0.93	0.93	1.24	2.17	3.72	3.67	9.00	10.62	0.59	2.25	3.11	2.80	10.30	14.30	95
	1.5+1.5+2.0+3.5+7.1	0.87	0.87	1.15	2.02	4.10	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95
	1.5+1.5+2.0+4.2+4.2	1.01	1.01	1.34	2.82	2.82	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95
	1.5+1.5+2.0+4.2+5.0	0.95	0.95	1.27	2.66	3.17	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95
	1.5+1.5+2.0+4.2+6.0	0.89	0.89	1.18	2.49	3.55	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95
	1.5+1.5+2.0+5.0+5.0	0.90	0.90	1.20	3.00	3.00	3.69	9.00	10.66	0.59	2.21	3.12	2.80	10.20	14.30	95
	1.5+1.5+2.5+2.5+2.5	1.24	1.24	2.07	2.07	2.07	2.92	8.70	9.50	0.53	2.14	2.51	2.44	9.80	11.60	95
	1.5+1.5+2.5+2.5+3.5	1.17	1.17	1.96	1.96	2.74	3.07	9.00	9.87	0.56	2.26	2.71	2.57	10.40	12.50	95
	1.5+1.5+2.5+2.5+4.2	1.11	1.11	1.84	1.84	3.10	3.17	9.00	10.09	0.60	2.26	2.84	2.74	10.40	13.00	95
	1.5+1.5+2.5+2.5+5.0	1.04	1.04	1.73	1.73	3.46	3.29	9.00	10.39	0.60	2.25	2.98	2.74	10.30	13.70	95
	1.5+1.5+2.5+2.5+6.0	0.96	0.96	1.61	1.61	3.86	3.48	9.00	10.61	0.56	2.25	3.11	2.60	10.30	14.30	95
	1.5+1.5+2.5+2.5+7.1	0.89	0.89	1.49	1.49	4.23	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95
	1.5+1.5+2.5+3.5+3.5	1.08	1.08	1.80	2.52	2.52	3.21	9.00	10.22	0.60	2.26	2.90	2.74	10.40	13.40	95
	1.5+1.5+2.5+3.5+4.2	1.02	1.02	1.70	2.39	2.86	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95
	1.5+1.5+2.5+3.5+5.0	0.96	0.96	1.61	2.25	3.21	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95
	1.5+1.5+2.5+3.5+6.0	0.90	0.90	1.50	2.10	3.60	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95
	1.5+1.5+2.5+4.2+4.2	0.97	0.97	1.62	2.72	2.72	3.47	9.00	10.23	0.56	2.26	2.90	2.70	10.40	13.40	95
	1.5+1.5+2.5+4.2+5.0	0.92	0.92	1.53	2.57	3.06	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95
	1.5+1.5+2.5+5.0+5.0	0.87	0.87	1.45	2.90	2.90	3.69	9.00	10.77	0.59	2.21	3.19	2.80	10.20	14.60	95
	1.5+1.5+3.5+3.5+3.5	1.00	1.00	2.33	2.33	2.33	3.47	9.00	10.24	0.56	2.26	2.91	2.70	10.40	13.40	95
	1.5+1.5+3.5+3.5+4.2	0.95	0.95	2.22	2.22	2.66	3.47	9.00	10.24	0.56	2.26	2.91	2.70	10.40	13.40	95
	1.5+1.5+3.5+3.5+5.0	0.90	0.90	2.10	2.10	3.00	3.67	9.00	10.73	0.59	2.25	3.18	2.80	10.30	14.60	95
	1.5+1.5+3.5+4.2+4.2	0.91	0.91	2.11	2.54	2.54	3.65	9.00	10.67	0.60	2.26	3.18	2.80	10.40	14.60	95
	1.5+2.0+2.0+2.0+2.0	1.26	1.68	1.68	1.68	1.68	2.77	8.00	8.99	0.53	1.85	2.27	2.44	8.50	10.40	95
	1.5+2.0+2.0+2.0+2.5	1.28	1.70	1.70	1.70	2.13	2.85	8.50	9.25	0.53	2.06	2.39	2.44	9.50	11.00	95
	1.5+2.0+2.0+2.0+3.5	1.23	1.64	1.64	1.64	2.86	2.99	9.00	9.74	0.56	2.26	2.64	2.57	10.40	12.10	95
	1.5+2.0+2.0+2.0+4.2	1.15	1.54	1.54	1.54	3.23	3.10	9.00	9.97	0.56	2.26	2.77	2.57	10.40	12.70	95
	1.5+2.0+2.0+2.0+5.0	1.08	1.44	1.44	1.44	3.60	3.21	9.00	10.27	0.60	2.25	2.91	2.74	10.40	13.40	95
1.5+2.0+2.0+2.0+6.0	1.00	1.33	1.33	1.33	4.00	3.48	9.00	10.49	0.56	2.25	3.04	2.60	10.30	14.00	95	
1.5+2.0+2.0+2.0+7.1	0.92	1.23	1.23	1.23	4.38	3.67	9.00	10.71	0.59	2.25	3.18	2.80	10.30	14.60	95	
1.5+2.0+2.0+2.5+2.5	1.24	1.66	1.66	2.07	2.07	2.92	8.70	9.49	0.53	2.14	2.51	2.44	9.80	11.60	95	
1.5+2.0+2.0+2.5+3.5	1.17	1.57	1.57	1.96	2.74	3.07	9.00	9.86	0.56	2.26	2.70	2.57	10.40	12.50	95	
1.5+2.0+2.0+2.5+4.2	1.11	1.48	1.48	1.84	3.10	3.17	9.00	10.09	0.60	2.26	2.84	2.74	10.40	13.00	95	
1.5+2.0+2.0+2.5+5.0	1.04	1.38	1.38	1.73	3.46	3.29	9.00	10.38	0.60	2.25	2.98	2.74	10.40	13.70	95	
1.5+2.0+2.0+2.5+6.0	0.96	1.29	1.29	1.61	3.86	3.48	9.00	10.61	0.56	2.25	3.11	2.60	10.30	14.30	95	
1.5+2.0+2.0+2.5+7.1	0.89	1.19	1.19	1.49	4.23	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	
1.5+2.0+2.0+3.5+3.5	1.08	1.44	1.44	2.52	2.52	3.21	9.00	10.21	0.60	2.26	2.90	2.74	10.40	13.40	95	
1.5+2.0+2.0+3.5+4.2	1.02	1.36	1.36	2.39	2.86	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	
1.5+2.0+2.0+3.5+5.0	0.96	1.29	1.29	2.25	3.21	3.48	9.00	10.40	0.56	2.25	2.98	2.60	10.30	13.70	95	
1.5+2.0+2.0+3.5+6.0	0.90	1.20	1.20	2.10	3.60	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	
1.5+2.0+2.0+4.2+4.2	0.97	1.29	1.29	2.72	2.72	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	
1.5+2.0+2.0+4.2+5.0	0.92	1.22	1.22	2.57	3.06	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	
1.5+2.0+2.0+5.0+5.0	0.87	1.16	1.16	2.90	2.90	3.69	9.00	10.77	0.59	2.21	3.19	2.80	10.20	14.60	95	
1.5+2.0+2.5+2.5+2.5	1.23	1.64	2.05	2.05	2.05	2.99	9.00	9.73	0.56	2.27	2.64	2.57	10.40	12.10	95	
1.5+2.0+2.5+2.5+3.5	1.13	1.50	1.88	1.88	2.63	3.14	9.00	10.09	0.56	2.26	2.84	2.57	10.40	13.00	95	
1.5+2.0+2.5+2.5+4.2	1.06	1.42	1.77	1.77	2.98	3.24	9.00	10.20	0.60	2.26	2.90	2.74	10.40	13.40	95	
1.5+2.0+2.5+2.5+5.0	1.00	1.33	1.67	1.67	3.33	3.48	9.00	10.39	0.56	2.25	2.98	2.60	10.30	13.70	95	
1.5+2.0+2.5+2.5+6.0	0.93	1.24	1.55	1.55	3.72	3.67	9.00	10.61	0.59	2.25	3.11	2.80	10.30	14.30	95	
1.5+2.0+2.5+2.5+7.1	0.87	1.15	1.44	1.44	4.10	3.67	9.00	10.72	0.59	2.25	3.18	2.80	10.30	14.60	95	
1.5+2.0+2.5+3.5+3.5	1.04	1.38	1.73	2.42	2.42	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	
1.5+2.0+2.5+3.5+4.2	0.99	1.31	1.64	2.30	2.76	3.46	9.00	10.22	0.56	2.26	2.90	2.70	10.40	13.40	95	
1.5+2.0+2.5+3.5+5.0	0.93	1.24	1.55	2.17	3.10	3.67	9.00	10.40	0.59	2.25	2.98	2.80	10.30	13.70	95	
1.5+2.0+2.5+3.5+6.0	0.87	1.16	1.45	2.03	3.48	3.67	9.00	10.7								