

Outdoor unit	Indoor unit	Heating capacity [kW]					Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room -A-	Room -B-	Room -C-	Room -D-	Room -E-	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
5MXM90M2V1B 5MXM90N2V1B 5MXM90N2V1B9 5MXM90A2V1B 5MXM90A2V1B9 5MXM90A2V1B8	1.5	2.70	-	-	-	-	1.28	2.70	4.16	0.28	0.44	0.84	1.29	2.04	3.90	95
	2.0	3.00	-	-	-	-	1.33	3.00	4.46	0.34	0.49	0.93	1.55	2.26	4.30	95
	2.5	3.40	-	-	-	-	1.39	3.40	4.91	0.36	0.60	1.07	1.64	2.75	5.00	95
	3.5	4.36	-	-	-	-	1.51	4.36	5.35	0.38	0.90	1.23	1.73	4.20	5.70	95
	4.2	5.23	-	-	-	-	1.56	5.23	6.20	0.40	1.18	1.52	1.82	5.40	7.10	95
	5.0	6.21	-	-	-	-	1.94	6.21	7.85	0.47	1.46	2.12	2.13	6.70	9.80	95
	6.0	7.46	-	-	-	-	2.23	7.46	9.12	0.58	1.96	2.75	2.66	9.00	12.70	95
	7.1	8.82	-	-	-	-	2.55	8.82	9.49	0.65	2.59	2.94	2.97	11.90	13.60	95
	1.5+1.5	1.85	1.85	-	-	-	1.51	3.70	7.47	0.37	0.67	1.83	1.68	3.10	8.40	95
	1.5+2.0	1.84	2.46	-	-	-	1.57	4.30	7.89	0.35	0.82	1.99	1.59	3.80	9.20	95
	1.5+2.5	1.84	3.06	-	-	-	1.72	4.90	8.03	0.37	0.99	2.03	1.68	4.60	9.40	95
	1.5+3.5	1.83	4.27	-	-	-	2.02	6.10	8.69	0.44	1.36	2.33	2.02	6.30	10.70	95
	1.5+4.2	1.84	5.16	-	-	-	2.23	7.00	8.98	0.42	1.64	2.39	1.94	7.50	11.00	95
	1.5+5.0	1.85	6.15	-	-	-	2.48	8.00	10.48	0.44	1.91	2.91	2.02	8.80	13.40	95
	1.5+6.0	1.80	7.20	-	-	-	2.87	9.00	10.74	0.46	2.29	3.03	2.20	10.50	13.90	95
	1.5+7.1	1.74	8.26	-	-	-	3.20	10.00	10.75	0.53	2.73	3.01	2.50	12.50	13.80	95
	2.0+2.0	2.45	2.45	-	-	-	1.72	4.90	8.03	0.37	0.99	2.03	1.68	4.60	9.40	95
	2.0+2.5	2.44	3.06	-	-	-	1.88	5.50	8.30	0.39	1.16	2.14	1.76	5.40	9.80	95
	2.0+3.5	2.44	4.26	-	-	-	2.17	6.70	8.83	0.47	1.56	2.38	2.15	7.20	10.90	95
	2.0+4.2	2.45	5.15	-	-	-	2.39	7.60	9.11	0.58	1.85	2.44	2.67	8.50	11.30	95
	2.0+5.0	2.43	6.07	-	-	-	2.71	8.50	10.74	0.43	2.10	3.03	2.10	9.70	13.90	95
	2.0+6.0	2.33	6.98	-	-	-	3.04	9.30	10.87	0.49	2.40	3.08	2.30	11.00	14.10	95
	2.0+7.1	2.20	7.80	-	-	-	3.36	10.00	11.01	0.56	2.71	3.12	2.60	12.50	14.40	95
	2.5+2.5	3.05	3.05	-	-	-	2.02	6.10	8.57	0.44	1.35	2.25	2.02	6.20	10.30	95
	2.5+3.5	3.04	4.26	-	-	-	2.33	7.30	9.22	0.56	1.77	2.55	2.58	8.10	11.70	95
	2.5+4.2	3.06	5.14	-	-	-	2.54	8.20	9.51	0.61	2.10	2.62	2.80	9.70	12.00	95
	2.5+5.0	3.00	6.00	-	-	-	2.87	9.00	10.74	0.46	2.28	3.02	2.20	10.50	13.90	95
	2.5+6.0	2.82	6.78	-	-	-	3.20	9.60	11.01	0.53	2.54	3.13	2.50	11.70	14.40	95
	2.5+7.1	2.60	7.40	-	-	-	3.52	10.00	11.27	0.59	2.70	3.24	2.80	12.40	14.90	95
	3.5+3.5	4.25	4.25	-	-	-	2.76	8.50	9.60	0.45	2.27	2.74	2.10	10.50	12.60	95
	3.5+4.2	4.09	4.91	-	-	-	2.91	9.00	10.26	0.48	2.45	3.00	2.20	11.30	13.80	95
	3.5+5.0	3.91	5.59	-	-	-	3.20	9.50	11.00	0.53	2.50	3.14	2.50	11.50	14.50	95
	3.5+6.0	3.68	6.32	-	-	-	3.36	10.00	11.25	0.56	2.72	3.26	2.60	12.50	15.00	95
	3.5+7.1	3.30	6.70	-	-	-	3.68	10.00	11.27	0.62	2.70	3.24	2.90	12.40	14.90	95
	4.2+4.2	4.75	4.75	-	-	-	3.06	9.50	10.05	0.50	2.60	2.81	2.40	12.00	12.90	95
	4.2+5.0	4.57	5.43	-	-	-	3.35	10.00	11.04	0.55	2.67	3.08	2.60	12.30	14.10	95
	4.2+6.0	4.12	5.88	-	-	-	3.68	10.00	11.30	0.62	2.63	3.19	2.90	12.10	14.60	95
	4.2+7.1	3.72	6.28	-	-	-	4.00	10.00	11.31	0.68	2.61	3.17	3.20	12.00	14.60	95
	5.0+5.0	5.00	5.00	-	-	-	3.65	10.00	11.13	0.60	2.49	2.91	2.80	11.50	13.40	95
	5.0+6.0	4.55	5.45	-	-	-	3.81	10.00	11.40	0.63	2.48	3.02	2.90	11.40	13.90	95
	5.0+7.1	4.13	5.87	-	-	-	4.13	10.00	11.41	0.69	2.47	3.00	3.30	11.30	13.80	95
	6.0+6.0	5.00	5.00	-	-	-	4.13	10.00	11.14	0.69	2.47	2.89	3.30	11.30	13.30	95
	6.0+7.1	4.58	5.42	-	-	-	4.45	10.00	11.28	0.76	2.45	2.93	3.50	11.30	13.50	95
	7.1+7.1	5.00	5.00	-	-	-	4.76	10.00	11.29	0.82	2.44	2.91	3.80	11.20	13.40	95
	1.5+1.5+1.5	1.83	1.83	1.83	-	-	1.88	5.50	10.04	0.44	1.05	2.52	2.02	4.80	11.60	95
	1.5+1.5+2.0	1.83	1.83	2.44	-	-	2.02	6.10	10.18	0.46	1.20	2.56	2.11	5.60	11.80	95
	1.5+1.5+2.5	1.83	1.83	3.05	-	-	2.17	6.70	10.31	0.48	1.37	2.61	2.19	6.30	12.00	95
	1.5+1.5+3.5	1.85	1.85	4.31	-	-	2.48	8.00	10.45	0.52	1.78	2.67	2.37	8.20	12.30	95
	1.5+1.5+4.2	1.81	1.81	5.08	-	-	2.83	8.70	10.47	0.45	1.99	2.61	2.10	9.20	12.00	95
	1.5+1.5+5.0	1.74	1.74	5.81	-	-	2.97	9.30	10.53	0.47	2.10	2.49	2.20	9.70	11.40	95
1.5+1.5+6.0	1.58	1.58	6.33	-	-	3.29	9.50	11.21	0.52	2.15	2.75	2.50	9.90	12.60	95	
1.5+1.5+7.1	1.49	1.49	7.03	-	-	3.62	10.00	11.21	0.58	2.33	2.73	2.70	10.70	12.60	95	
1.5+2.0+2.0	1.83	2.44	2.44	-	-	2.17	6.70	10.31	0.48	1.37	2.61	2.19	6.30	12.00	95	
1.5+2.0+2.5	1.83	2.43	3.04	-	-	2.33	7.30	10.45	0.50	1.55	2.66	2.28	7.10	12.20	95	
1.5+2.0+3.5	1.82	2.43	4.25	-	-	2.67	8.50	10.58	0.42	1.94	2.71	2.00	8.90	12.50	95	
1.5+2.0+4.2	1.75	2.34	4.91	-	-	2.99	9.00	10.61	0.48	2.09	2.66	2.20	9.60	12.30	95	
1.5+2.0+5.0	1.76	2.35	5.88	-	-	3.13	10.00	10.94	0.49	2.35	2.64	2.30	10.80	12.20	95	
1.5+2.0+6.0	1.58	2.11	6.32	-	-	3.46	10.00	11.21	0.55	2.33	2.74	2.60	10.70	12.60	95	
1.5+2.0+7.1	1.42	1.89	6.70	-	-	3.78	10.00	11.22	0.61	2.32	2.73	2.80	10.70	12.50	95	
1.5+2.5+2.5	1.85	3.08	3.08	-	-	2.48	8.00	10.59	0.52	1.77	2.70	2.37	8.20	12.50	95	
1.5+2.5+3.5	1.80	3.00	4.20	-	-	2.83	9.00	10.72	0.45	2.13	2.76	2.10	9.80	12.70	95	
1.5+2.5+4.2	1.83	3.05	5.12	-	-	2.99	10.00	10.75	0.47	2.46	2.71	2.20	11.30	12.50	95	
1.5+2.5+5.0	1.67	2.78	5.56	-	-	3.29	10.00	11.08	0.52	2.34	2.69	2.50	10.70	12.40	95	
1.5+2.5+6.0	1.50	2.50	6.00	-	-	3.62	10.00	11.22	0.58	2.33	2.73	2.70	10.70	12.50	95	
1.5+2.5+7.1	1.35	2.25	6.40	-	-	3.94	10.00	11.22	0.64	2.31	2.72	3.00	10.60	12.50	95	
1.5+3.5+3.5	1.76	4.12	4.12	-	-	3.16	10.00	10.72	0.51	2.51	2.76	2.40	11.60	12.70	95	
1.5+3.5+4.2	1.63	3.80	4.57	-	-	3.32	10.00	10.88	0.53	2.46	2.76	2.50	11.30	12.70	95	
1.5+3.5+5.0	1.50	3.50	5.00	-	-	3.62	10.00	11.08	0.58	2.34	2.69	2.70	10.70	12.40	95	
1.5+3.5+6.0	1.36	3.18	5.45	-	-	3.78	10.00	11.22	0.61	2.33	2.73	2.80	10.70	12.50	95	
1.5+3.5+7.1	1.24	2.89	5.87	-	-	4.10	10.00	11.22	0.67	2.31	2.72	3.10	10.60	12.50	95	
1.5+4.2+4.2	1.52	4.24	4.24	-	-	3.47	10.00	10.91	0.56	2.41	2.71	2.60	11.10	12.50	95	
1.5+4.2+5.0	1.40	3.93	4.67	-	-	3.77	10.00	11.09	0.60	2.30	2.64	2.80	10.60	12.20	95	
1.5+4.2+6.0	1.28	3.59	5.13	-	-	4.10	10.00	11.37	0.66	2.29	2.74	3.10	10.50	12.60	95	
1.5+4.2+7.1	1.17	3.28	5.55	-	-	4.42	10.00	11.37	0.72	2.28	2.72	3.40	10.50	12.50	95	
1.5+5.0+5.0	1.30	4.35	4.35	-	-	4.08	10.00	11.26	0.65	2.18	2.58	3.00	10.00	11.90	95	
1.5+5.0+6.0	1.20	4.00	4.80	-	-	4.24	10.00	11.54	0.68	2.18	2.68	3.20	10.00	12.30	95	
1.5+5.0+7.1	1.10	3.68	5.22	-	-	4.56	10.00	11.54	0.73	2.17	2.67	3.40	10.00	12.30	95	
1.5+6.0+6.0	1.11	4.44	4.44	-	-	4.56	10.00	11.68	0.73	2.17	2.72	3.40	10.00	12.50	95	
1.5+6.0+7.1	1.32	3.97	4.70	-	-	4.88	10.00	11.68	0.79	2.15	2.70	3.70	9.90	12.50	95	
2.0+2.0+2.0	2.50	2.50	2.50	-	-	2.33	7.50	10.58	0.50	1.60	2.71	2.28	7.40	12.50	95	
2.0+2.0+2.5	2.46	2.46	3.08	-	-	2.48	8.00	10.59	0.52	1.77	2.70	2.37	8.20	12.50	95	
2.0+2.0+3.5	2.40	2.40	4.20	-	-	2.83	9.00	10.72	0.45	2.13	2.76	2.10	9.80	12.70	95	
2.0+2.0+4.2	2.29	2.29	4.81	-	-	2.99	9.40	10.75	0.47	2.24	2.71	2.20	10.30	12.50	95	