

Outdoor unit	Indoor unit	Heating capacity [kW]					Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room -A-	Room -B-	Room -C-	Room -D-	Room -E-	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
	2.0+2.0+5.0	2.22	2.22	5.56	-	-	3.29	10.00	10.94	0.52	2.34	2.63	2.50	10.70	12.10	95
	2.0+2.0+6.0	2.00	2.00	6.00	-	-	3.62	10.00	11.22	0.58	2.33	2.73	2.70	10.70	12.50	95
	2.0+2.0+7.1	1.80	1.80	6.40	-	-	3.94	10.00	11.22	0.64	2.32	2.72	3.00	10.60	12.50	95
	2.0+2.5+2.5	2.43	3.04	3.04	-	-	2.67	8.50	10.59	0.42	1.93	2.69	2.00	8.90	12.40	95
	2.0+2.5+3.5	2.33	2.91	4.07	-	-	3.00	9.30	10.73	0.48	2.23	2.75	2.20	10.20	12.70	95
	2.0+2.5+4.2	2.30	2.87	4.83	-	-	3.15	10.00	10.89	0.50	2.45	2.75	2.40	11.30	12.70	95
	2.0+2.5+5.0	2.11	2.63	5.26	-	-	3.45	10.00	11.21	0.55	2.33	2.73	2.60	10.70	12.60	95
	2.0+2.5+6.0	1.90	2.38	5.71	-	-	3.78	10.00	11.22	0.61	2.32	2.72	2.80	10.70	12.50	95
	2.0+2.5+7.1	1.72	2.16	6.12	-	-	4.10	10.00	11.22	0.67	2.31	2.71	3.10	10.60	12.50	95
	2.0+3.5+3.5	2.22	3.89	3.89	-	-	3.33	10.00	10.86	0.54	2.50	2.81	2.50	11.50	12.90	95
	2.0+3.5+4.2	2.06	3.61	4.33	-	-	3.48	10.00	11.02	0.56	2.45	2.81	2.70	11.30	13.00	95
	2.0+3.5+5.0	1.90	3.33	4.76	-	-	3.78	10.00	11.35	0.61	2.33	2.79	2.80	10.70	12.80	95
	2.0+3.5+6.0	1.74	3.04	5.22	-	-	3.94	10.00	11.35	0.64	2.32	2.78	3.00	10.70	12.80	95
	2.0+3.5+7.1	1.59	2.78	5.63	-	-	4.26	10.00	11.36	0.70	2.31	2.76	3.30	10.60	12.70	95
	2.0+4.2+4.2	1.92	4.04	4.04	-	-	3.63	10.00	11.04	0.59	2.40	2.76	2.80	11.10	12.70	95
	2.0+4.2+5.0	1.79	3.75	4.46	-	-	3.93	10.00	11.37	0.63	2.29	2.74	3.00	10.50	12.60	95
	2.0+4.2+6.0	1.64	3.44	4.92	-	-	4.26	10.00	11.37	0.69	2.28	2.73	3.30	10.50	12.50	95
	2.0+4.2+7.1	1.50	3.16	5.34	-	-	4.58	10.00	11.51	0.75	2.27	2.77	3.50	10.40	12.80	95
	2.0+5.0+5.0	1.67	4.17	4.17	-	-	4.08	10.00	11.13	0.65	2.18	2.53	3.00	10.00	11.60	95
	2.0+5.0+6.0	1.54	3.85	4.62	-	-	4.40	10.00	11.41	0.70	2.17	2.62	3.30	10.00	12.00	95
	2.0+5.0+7.1	1.42	3.55	5.04	-	-	4.72	10.00	11.41	0.76	2.16	2.61	3.60	9.90	12.00	95
	2.0+6.0+6.0	1.43	4.29	4.29	-	-	4.72	10.00	11.54	0.76	2.16	2.66	3.60	9.90	12.30	95
	2.0+6.0+7.1	1.32	3.97	4.70	-	-	5.04	10.00	11.68	0.82	2.15	2.70	3.80	9.90	12.50	95
	2.5+2.5+2.5	3.33	3.33	3.33	-	-	2.83	10.00	10.73	0.45	2.49	2.74	2.10	11.50	12.60	95
	2.5+2.5+3.5	2.94	2.94	4.12	-	-	3.16	10.00	11.00	0.51	2.49	2.86	2.40	11.50	13.10	95
	2.5+2.5+4.2	2.72	2.72	4.57	-	-	3.31	10.00	11.16	0.53	2.44	2.86	2.50	11.20	13.10	95
	2.5+2.5+5.0	2.50	2.50	5.00	-	-	3.62	10.00	11.35	0.58	2.32	2.78	2.70	10.70	12.80	95
	2.5+2.5+6.0	2.27	2.27	5.45	-	-	3.78	10.00	11.36	0.61	2.31	2.77	2.80	10.60	12.70	95
	2.5+2.5+7.1	2.07	2.07	5.87	-	-	4.10	10.00	11.50	0.66	2.30	2.81	3.10	10.60	12.90	95
	2.5+3.5+3.5	2.63	3.68	3.68	-	-	3.49	10.00	11.26	0.57	2.49	2.97	2.70	11.50	13.70	95
	2.5+3.5+4.2	2.45	3.43	4.12	-	-	3.64	10.00	11.29	0.59	2.44	2.92	2.80	11.20	13.40	95
	2.5+3.5+5.0	2.27	3.18	4.55	-	-	3.78	10.00	11.35	0.61	2.32	2.78	2.80	10.70	12.80	95
	2.5+3.5+6.0	2.08	2.92	5.00	-	-	4.10	10.00	11.36	0.67	2.31	2.77	3.10	10.60	12.70	95
	2.5+3.5+7.1	1.91	2.67	5.42	-	-	4.42	10.00	11.50	0.73	2.30	2.81	3.40	10.60	12.90	95
	2.5+4.2+4.2	2.29	3.85	3.85	-	-	3.79	10.00	11.31	0.62	2.40	2.86	2.90	11.00	13.20	95
	2.5+4.2+5.0	2.14	3.59	4.27	-	-	4.10	10.00	11.37	0.66	2.28	2.73	3.10	10.50	12.60	95
	2.5+4.2+6.0	1.97	3.31	4.72	-	-	4.42	10.00	11.38	0.72	2.27	2.72	3.40	10.40	12.50	95
	2.5+4.2+7.1	1.81	3.04	5.14	-	-	4.73	10.00	11.52	0.78	2.26	2.76	3.70	10.40	12.70	95
	2.5+5.0+5.0	2.00	4.00	4.00	-	-	4.24	10.00	11.13	0.67	2.17	2.52	3.20	10.00	11.60	95
	2.5+5.0+6.0	1.85	3.70	4.44	-	-	4.56	10.00	11.41	0.73	2.16	2.61	3.40	10.00	12.00	95
5MXM90M2V1B	2.5+5.0+7.1	1.71	3.42	4.86	-	-	4.88	10.00	11.41	0.79	2.16	2.60	3.70	9.90	12.00	95
5MXM90N2V1B9	2.5+6.0+6.0	1.72	4.14	4.14	-	-	4.88	10.00	11.55	0.79	2.16	2.65	3.70	9.90	12.20	95
5MXM90A2V1B	2.5+6.0+7.1	1.60	3.85	4.55	-	-	5.19	10.00	11.68	0.85	2.15	2.70	4.00	9.90	12.40	95
5MXM90A2V1B9	3.5+3.5+3.5	3.33	3.33	3.33	-	-	3.65	10.00	11.26	0.60	2.49	2.97	2.80	11.50	13.70	95
5MXM90A2V1B8	3.5+3.5+4.2	3.13	3.13	3.75	-	-	3.96	10.00	11.29	0.66	2.44	2.92	3.10	11.20	13.40	95
	3.5+3.5+5.0	2.92	2.92	4.17	-	-	4.10	10.00	11.35	0.67	2.32	2.78	3.10	10.70	12.80	95
	3.5+3.5+6.0	2.69	2.69	4.62	-	-	4.42	10.00	11.49	0.73	2.31	2.82	3.40	10.60	13.00	95
	3.5+3.5+7.1	2.48	2.48	5.04	-	-	4.74	10.00	11.50	0.79	2.30	2.81	3.70	10.60	12.90	95
	3.5+4.2+4.2	2.94	3.53	3.53	-	-	4.12	10.00	11.31	0.68	2.40	2.86	3.20	11.00	13.20	95
	3.5+4.2+5.0	2.76	3.31	3.94	-	-	4.42	10.00	11.36	0.72	2.28	2.71	3.40	10.50	12.39	95
	3.5+4.2+6.0	2.55	3.07	4.38	-	-	4.58	10.00	11.38	0.75	2.27	2.72	3.50	10.40	12.50	95
	3.5+4.2+7.1	2.36	2.84	4.80	-	-	4.89	10.00	11.38	0.81	2.26	2.71	3.80	10.40	12.50	95
	3.5+5.0+5.0	2.59	3.70	3.70	-	-	4.56	10.00	11.13	0.73	2.17	2.52	3.40	10.00	11.60	95
	3.5+5.0+6.0	2.41	3.45	4.14	-	-	4.88	10.00	11.41	0.80	2.16	2.61	3.70	10.00	12.00	95
	3.5+5.0+7.1	2.24	3.21	4.55	-	-	5.20	10.00	11.41	0.86	2.16	2.60	4.00	9.90	12.00	95
	3.5+6.0+6.0	2.26	3.87	3.87	-	-	5.20	10.00	11.55	0.86	2.16	2.65	4.00	9.90	12.20	95
	4.2+4.2+4.2	3.33	3.33	3.33	-	-	4.27	10.00	11.34	0.70	2.35	2.81	3.30	10.80	13.00	95
	4.2+4.2+5.0	3.13	3.13	3.73	-	-	4.57	10.00	11.37	0.75	2.23	2.66	3.50	10.20	12.19	95
	4.2+4.2+6.0	2.92	2.92	4.17	-	-	4.89	10.00	11.39	0.81	2.22	2.68	3.80	10.20	12.30	95
	4.2+4.2+7.1	2.71	2.71	4.58	-	-	5.21	10.00	11.39	0.87	2.21	2.67	4.10	10.20	12.30	95
	4.2+5.0+5.0	2.96	3.52	3.52	-	-	4.71	10.00	11.14	0.76	2.14	2.48	3.50	9.90	11.40	95
	4.2+5.0+6.0	2.76	3.29	3.95	-	-	5.03	10.00	11.41	0.82	2.14	2.58	3.80	9.80	11.90	95
	5.0+5.0+5.0	3.33	3.33	3.33	-	-	5.02	10.00	11.28	0.80	2.08	2.45	3.80	9.60	11.30	95
	1.5+1.5+1.5+1.5	1.83	1.83	1.83	1.83	-	2.33	7.30	10.14	0.43	1.40	2.23	1.98	6.50	10.30	95
	1.5+1.5+1.5+2.0	1.85	1.85	1.85	2.46	-	2.61	8.00	10.42	0.40	1.60	2.32	1.90	7.40	10.70	95
	1.5+1.5+1.5+2.5	1.82	1.82	1.82	3.04	-	2.77	8.50	10.43	0.43	1.73	2.31	2.00	8.00	10.70	95
	1.5+1.5+1.5+3.5	1.74	1.74	1.74	4.07	-	2.94	9.30	10.71	0.45	1.99	2.41	2.20	9.20	11.10	95
	1.5+1.5+1.5+4.2	1.72	1.72	1.72	4.83	-	3.26	10.00	11.27	0.50	2.18	2.58	2.40	10.00	11.90	95
	1.5+1.5+1.5+5.0	1.58	1.58	1.58	5.26	-	3.41	10.00	11.42	0.52	2.10	2.54	2.50	9.70	11.70	95
	1.5+1.5+1.5+6.0	1.43	1.43	1.43	5.71	-	3.73	10.00	11.55	0.58	2.10	2.58	2.70	9.70	11.90	95
	1.5+1.5+1.5+7.1	1.29	1.29	1.29	6.12	-	4.06	10.00	11.69	0.63	2.09	2.62	3.00	9.60	12.10	95
	1.5+1.5+2.0+2.0	1.82	1.82	2.43	2.43	-	2.77	8.50	10.57	0.43	1.73	2.36	2.00	8.00	10.90	95
	1.5+1.5+2.0+2.5	1.80	1.80	2.40	3.00	-	2.94	9.00	10.71	0.45	1.87	2.40	2.20	8.60	11.10	95
	1.5+1.5+2.0+3.5	1.76	1.76	2.35	4.12	-	3.10	10.00	10.71	0.48	2.20	2.40	2.30	10.10	11.10	95
	1.5+1.5+2.0+4.2	1.63	1.63	2.17	4.57	-	3.42	10.00	11.27	0.53	2.17	2.57	2.50	10.00	11.80	95
	1.5+1.5+2.0+5.0	1.50	1.50	2.00	5.00	-	3.57	10.00	11.42	0.55	2.10	2.53	2.60	9.70	11.70	95
	1.5+1.5+2.0+6.0	1.36	1.36	1.82	5.45	-	3.89	10.00	11.55	0.60	2.09	2.57	2.80	9.60	11.90	95
	1.5+1.5+2.0+7.1	1.24	1.24													