

Outdoor unit	Indoor unit	Heating capacity [kW]					Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room -A-	Room -B-	Room -C-	Room -D-	Room -E-	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
5MXM90M2V1B	2.0+2.0+3.5+7.1	1.37	1.37	2.40	4.86	-	4.86	10.00	11.69	0.77	2.08	2.60	3.60	9.60	11.90	95
	2.0+2.0+4.2+4.2	1.61	1.61	3.39	3.39	-	4.23	10.00	11.28	0.67	2.13	2.52	3.10	9.80	11.60	95
	2.0+2.0+4.2+5.0	1.52	1.52	3.18	3.79	-	4.53	10.00	11.41	0.71	2.07	2.49	3.30	9.50	11.40	95
	2.0+2.0+4.2+6.0	1.41	1.41	2.96	4.23	-	4.85	10.00	11.68	0.77	2.06	2.58	3.60	9.50	11.90	95
	2.0+2.0+4.2+7.1	1.31	1.31	2.75	4.64	-	5.17	10.00	11.69	0.83	2.06	2.57	3.80	9.50	11.78	95
	2.0+2.0+5.0+5.0	1.43	1.43	3.57	3.57	-	4.68	10.00	11.52	0.73	2.04	2.48	3.40	9.40	11.40	95
	2.0+2.0+5.0+6.0	1.33	1.33	3.33	4.00	-	5.00	10.00	11.79	0.79	2.04	2.57	3.70	9.40	11.90	95
	2.0+2.5+2.5+2.5	2.11	2.63	2.63	2.63	-	3.42	10.00	11.27	0.53	2.18	2.58	2.50	10.00	11.90	95
	2.0+2.5+2.5+3.5	1.90	2.38	2.38	3.33	-	3.75	10.00	11.27	0.59	2.18	2.58	2.80	10.00	11.90	95
	2.0+2.5+2.5+4.2	1.79	2.23	2.23	3.75	-	3.91	10.00	11.27	0.61	2.15	2.54	2.90	9.90	11.70	95
	2.0+2.5+2.5+5.0	1.67	2.08	2.08	4.17	-	4.22	10.00	11.41	0.66	2.08	2.51	3.10	9.60	11.50	95
	2.0+2.5+2.5+6.0	1.54	1.92	1.92	4.62	-	4.38	10.00	11.55	0.69	2.08	2.55	3.20	9.60	11.80	95
	2.0+2.5+2.5+7.1	1.42	1.77	1.77	5.04	-	4.70	10.00	11.69	0.74	2.07	2.59	3.50	9.50	11.90	95
	2.0+2.5+3.5+3.5	1.74	2.17	3.04	3.04	-	4.08	10.00	11.27	0.65	2.18	2.58	3.00	10.00	11.90	95
	2.0+2.5+3.5+4.2	1.64	2.05	2.87	3.44	-	4.23	10.00	11.27	0.67	2.15	2.54	3.20	9.90	11.70	95
	2.0+2.5+3.5+5.0	1.54	1.92	2.69	3.85	-	4.38	10.00	11.41	0.69	2.08	2.51	3.20	9.60	11.50	95
	2.0+2.5+3.5+6.0	1.43	1.79	2.50	4.29	-	4.70	10.00	11.55	0.74	2.08	2.55	3.50	9.60	11.80	95
	2.0+2.5+3.5+7.1	1.32	1.66	2.32	4.70	-	5.02	10.00	11.69	0.80	2.07	2.59	3.80	9.50	11.90	95
	2.0+2.5+4.2+4.2	1.55	1.94	3.26	3.26	-	4.39	10.00	11.28	0.69	2.12	2.51	3.30	9.80	11.50	95
	2.0+2.5+4.2+5.0	1.46	1.82	3.07	3.65	-	4.69	10.00	11.41	0.74	2.06	2.48	3.50	9.50	11.40	95
	2.0+2.5+4.2+6.0	1.36	1.70	2.86	4.08	-	4.85	10.00	11.68	0.77	2.06	2.57	3.60	9.50	11.90	95
	2.0+2.5+5.0+5.0	1.38	1.72	3.45	3.45	-	4.84	10.00	11.52	0.76	2.04	2.48	3.50	9.40	11.40	95
	2.0+2.5+5.0+6.0	1.29	1.61	3.23	3.87	-	5.16	10.00	11.79	0.82	2.04	2.57	3.80	9.40	11.80	95
	2.0+3.5+3.5+3.5	1.60	2.80	2.80	2.80	-	4.24	10.00	11.27	0.68	2.18	2.58	3.20	10.00	11.90	95
	2.0+3.5+3.5+4.2	1.52	2.65	2.65	3.18	-	4.55	10.00	11.27	0.73	2.15	2.54	3.40	9.90	11.70	95
	2.0+3.5+3.5+5.0	1.43	2.50	2.50	3.57	-	4.70	10.00	11.41	0.74	2.08	2.51	3.50	9.60	11.50	95
	2.0+3.5+3.5+6.0	1.33	2.33	2.33	4.00	-	5.02	10.00	11.69	0.80	2.08	2.60	3.80	9.60	12.00	95
	2.0+3.5+4.2+4.2	1.44	2.52	3.02	3.02	-	4.71	10.00	11.28	0.75	2.12	2.51	3.50	9.80	11.50	95
	2.0+3.5+4.2+5.0	1.36	2.38	2.86	3.40	-	4.85	10.00	11.41	0.77	2.06	2.48	3.60	9.50	11.40	95
	2.0+3.5+5.0+5.0	1.29	2.26	3.23	3.23	-	5.16	10.00	11.52	0.82	2.04	2.48	3.80	9.40	11.40	95
	2.0+4.2+4.2+4.2	1.37	2.88	2.88	2.88	-	4.86	10.00	11.28	0.78	2.10	2.48	3.60	9.70	11.40	95
	2.0+4.2+4.2+5.0	1.30	2.73	2.73	3.25	-	5.17	10.00	11.40	0.83	2.06	2.46	3.80	9.50	11.40	95
	2.5+2.5+2.5+2.5	2.50	2.50	2.50	2.50	-	3.59	10.00	11.27	0.56	2.17	2.57	2.60	10.00	11.90	95
	2.5+2.5+2.5+3.5	2.27	2.27	2.27	3.18	-	3.91	10.00	11.27	0.62	2.17	2.57	2.90	10.00	11.90	95
	2.5+2.5+2.5+4.2	2.14	2.14	2.14	3.59	-	4.07	10.00	11.27	0.64	2.14	2.54	3.00	9.90	11.70	95
	2.5+2.5+2.5+5.0	2.00	2.00	2.00	4.00	-	4.21	10.00	11.41	0.66	2.08	2.50	3.10	9.60	11.50	95
	2.5+2.5+2.5+6.0	1.85	1.85	1.85	4.44	-	4.54	10.00	11.55	0.71	2.07	2.55	3.30	9.50	11.70	95
	2.5+2.5+2.5+7.1	1.71	1.71	1.71	4.86	-	4.86	10.00	11.69	0.77	2.07	2.59	3.60	9.50	11.90	95
	2.5+2.5+3.5+3.5	2.08	2.08	2.92	2.92	-	4.08	10.00	11.27	0.65	2.17	2.57	3.00	10.00	11.90	95
	2.5+2.5+3.5+4.2	1.97	1.97	2.76	3.31	-	4.39	10.00	11.27	0.70	2.14	2.54	3.30	9.90	11.70	95
	2.5+2.5+3.5+5.0	1.85	1.85	2.59	3.70	-	4.54	10.00	11.41	0.71	2.08	2.50	3.30	9.60	11.50	95
	2.5+2.5+3.5+6.0	1.72	1.72	2.41	4.14	-	4.86	10.00	11.55	0.77	2.07	2.55	3.60	9.50	11.70	95
2.5+2.5+3.5+7.1	1.60	1.60	2.24	4.55	-	5.17	10.00	11.69	0.83	2.07	2.59	3.90	9.50	11.90	95	
2.5+2.5+4.2+4.2	1.87	1.87	3.13	3.13	-	4.55	10.00	11.28	0.72	2.12	2.50	3.40	9.70	11.50	95	
2.5+2.5+4.2+5.0	1.76	1.76	2.96	3.52	-	4.85	10.00	11.41	0.77	2.06	2.48	3.60	9.50	11.40	95	
2.5+2.5+4.2+6.0	1.64	1.64	2.76	3.95	-	5.01	10.00	11.68	0.80	2.06	2.57	3.70	9.50	11.80	95	
2.5+2.5+5.0+5.0	1.67	1.67	3.33	3.33	-	5.00	10.00	11.52	0.79	2.04	2.47	3.70	9.40	11.40	95	
2.5+3.5+3.5+3.5	1.92	2.69	2.69	2.69	-	4.40	10.00	11.27	0.70	2.17	2.57	3.30	10.00	11.90	95	
2.5+3.5+3.5+4.2	1.82	2.55	2.55	3.07	-	4.55	10.00	11.27	0.73	2.14	2.54	3.40	9.90	11.70	95	
2.5+3.5+3.5+5.0	1.72	2.41	2.41	3.45	-	4.86	10.00	11.41	0.77	2.08	2.50	3.60	9.60	11.50	95	
2.5+3.5+3.5+6.0	1.61	2.26	2.26	3.87	-	5.18	10.00	11.69	0.83	2.07	2.60	3.90	9.50	11.90	95	
2.5+3.5+4.2+4.2	1.74	2.43	2.92	2.92	-	4.87	10.00	11.28	0.78	2.12	2.50	3.70	9.70	11.50	95	
2.5+3.5+4.2+5.0	1.64	2.30	2.76	3.29	-	5.01	10.00	11.41	0.80	2.06	2.48	3.70	9.50	11.40	95	
2.5+4.2+4.2+4.2	1.66	2.78	2.78	2.78	-	5.02	10.00	11.28	0.81	2.09	2.47	3.80	9.60	11.40	95	
3.5+3.5+3.5+3.5	2.50	2.50	2.50	2.50	-	4.72	10.00	11.27	0.77	2.17	2.57	3.60	10.00	11.90	95	
3.5+3.5+3.5+4.2	2.38	2.38	2.38	2.86	-	4.87	10.00	11.27	0.79	2.14	2.54	3.70	9.90	11.70	95	
3.5+3.5+3.5+5.0	2.26	2.26	2.26	3.23	-	5.18	10.00	11.41	0.83	2.08	2.50	3.90	9.60	11.50	95	
3.5+3.5+4.2+4.2	2.27	2.27	2.73	2.73	-	5.19	10.00	11.28	0.85	2.12	2.50	3.90	9.70	11.50	95	
1.5+1.5+1.5+1.5+1.5	2.00	2.00	2.00	2.00	2.00	2.89	10.00	10.99	0.44	2.06	2.32	2.10	9.50	10.70	95	
1.5+1.5+1.5+1.5+2.0	1.88	1.88	1.88	1.88	2.50	3.06	10.00	11.00	0.47	2.06	2.32	2.20	9.50	10.62	95	
1.5+1.5+1.5+1.5+2.5	1.76	1.76	1.76	1.76	2.94	3.22	10.00	11.01	0.49	2.06	2.32	2.30	9.50	10.62	95	
1.5+1.5+1.5+1.5+3.5	1.58	1.58	1.58	1.58	3.68	3.39	10.00	11.67	0.52	2.06	2.55	2.40	9.50	11.80	95	
1.5+1.5+1.5+1.5+4.2	1.47	1.47	1.47	1.47	4.12	3.71	10.00	11.68	0.57	2.04	2.53	2.70	9.40	11.60	95	
1.5+1.5+1.5+1.5+5.0	1.36	1.36	1.36	1.36	4.55	3.86	10.00	11.75	0.59	2.02	2.54	2.80	9.30	11.70	95	
1.5+1.5+1.5+1.5+6.0	1.25	1.25	1.25	1.25	5.00	4.19	10.00	12.01	0.64	2.02	2.63	3.00	9.30	12.10	95	
1.5+1.5+1.5+1.5+7.1	1.15	1.15	1.15	1.15	5.42	4.51	10.00	12.02	0.70	2.02	2.63	3.30	9.30	12.05	95	
1.5+1.5+1.5+2.0+2.0	1.76	1.76	1.76	2.35	2.35	3.22	10.00	10.98	0.49	2.06	2.31	2.30	9.50	10.70	95	
1.5+1.5+1.5+2.0+2.5	1.67	1.67	1.67	2.22	2.78	3.22	10.00	11.67	0.49	2.06	2.55	2.30	9.50	11.70	95	
1.5+1.5+1.5+2.0+3.5	1.50	1.50	1.50	2.00	3.50	3.55	10.00	11.67	0.54	2.06	2.55	2.60	9.50	11.70	95	
1.5+1.5+1.5+2.0+4.2	1.40	1.40	1.40	1.87	3.93	3.71	10.00	11.68	0.57	2.04	2.53	2.70	9.40	11.59	95	
1.5+1.5+1.5+2.0+5.0	1.30	1.30	1.30	1.74	4.35	4.02	10.00	11.74	0.62	2.02	2.54	2.90	9.30	11.70	95	
1.5+1.5+1.5+2.0+6.0	1.20	1.20	1.20	1.60	4.80	4.35	10.00	12.00	0.67	2.02	2.63	3.10	9.30	12.10	95	
1.5+1.5+1.5+2.0+7.1	1.10	1.10	1.10	1.47	5.22	4.67	10.00	12.01	0.73	2.02	2.63	3.40	9.30	12.04	95	
1.5+1.5+1.5+2.5+2.5	1.58	1.58	1.58	2.63	2.63	3.39	10.00	11.67	0.52	2.05	2.54	2.40	9.40	11.70	95	
1.5+1.5+1.5+2.5+3.5	1.43	1.43	1.43	2.38	3.33	3.71	10.00	11.67	0.57	2.05	2.54	2.70	9.40	11.70	95	
1.5+1.5+1.5+2.5+4.2	1.34	1.34	1.34	2.23	3.75	3.87	10.00	11.69								