

Heating -230V 50Hz-

Outdoor unit	Indoor unit	Heating capacity [kW]					Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room -A-	Room -B-	Room -C-	Room -D-	Room -E-	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
5MXM90M2V1B 5MXM90N2V1B 5MXM90N2V1B9 5MXM90A2V1B 5MXM90A2V1B9 5MXM90A2V1B8	1.5+2.5+2.5+2.5+6.0	1.00	1.67	1.67	1.67	4.00	4.98	10.00	11.97	0.78	2.02	2.62	3.70	9.30	12.10	95
	1.5+2.5+2.5+3.5+3.5	1.11	1.85	1.85	2.59	2.59	4.52	10.00	11.66	0.70	2.04	2.53	3.30	9.40	11.60	95
	1.5+2.5+2.5+3.5+4.2	1.06	1.76	1.76	2.46	2.96	4.84	10.00	11.67	0.76	2.03	2.52	3.50	9.40	11.52	95
	1.5+2.5+2.5+3.5+5.0	1.00	1.67	1.67	2.33	3.33	4.98	10.00	11.71	0.78	2.02	2.53	3.70	9.30	11.60	95
	1.5+2.5+2.5+4.2+4.2	1.01	1.68	1.68	2.82	2.82	4.99	10.00	11.62	0.78	2.03	2.50	3.70	9.30	11.50	95
	1.5+2.5+3.5+3.5+3.5	1.03	1.72	2.41	2.41	2.41	4.84	10.00	11.66	0.76	2.04	2.53	3.60	9.40	11.60	95
	1.5+2.5+3.5+3.5+4.2	0.99	1.64	2.30	2.30	2.76	5.00	10.00	11.67	0.79	2.03	2.52	3.70	9.40	11.52	95
	1.5+3.5+3.5+3.5+3.5	0.97	2.26	2.26	2.26	2.26	5.16	10.00	11.68	0.82	2.04	2.53	3.80	9.40	11.59	95
	2.0+2.0+2.0+2.0+2.0	2.00	2.00	2.00	2.00	2.00	3.55	10.00	11.67	0.54	2.05	2.54	2.60	9.40	11.70	95
	2.0+2.0+2.0+2.0+2.5	1.90	1.90	1.90	1.90	2.38	3.71	10.00	11.68	0.57	2.05	2.54	2.70	9.40	11.62	95
	2.0+2.0+2.0+2.0+3.5	1.74	1.74	1.74	1.74	3.04	4.04	10.00	11.69	0.62	2.05	2.54	2.90	9.40	11.63	95
	2.0+2.0+2.0+2.0+4.2	1.64	1.64	1.64	1.64	3.44	4.20	10.00	11.70	0.65	2.04	2.53	3.00	9.40	11.57	95
	2.0+2.0+2.0+2.0+5.0	1.54	1.54	1.54	1.54	3.85	4.51	10.00	11.73	0.70	2.02	2.53	3.30	9.30	11.70	95
	2.0+2.0+2.0+2.0+6.0	1.43	1.43	1.43	1.43	4.29	4.67	10.00	11.99	0.73	2.02	2.62	3.40	9.30	12.10	95
	2.0+2.0+2.0+2.0+7.1	1.32	1.32	1.32	1.32	4.70	4.98	10.00	12.00	0.78	2.02	2.63	3.70	9.30	12.03	95
	2.0+2.0+2.0+2.5+2.5	1.82	1.82	1.82	2.27	2.27	3.87	10.00	11.66	0.59	2.05	2.53	2.80	9.40	11.70	95
	2.0+2.0+2.0+2.5+3.5	1.67	1.67	1.67	2.08	2.92	4.20	10.00	11.66	0.65	2.05	2.53	3.00	9.40	11.70	95
	2.0+2.0+2.0+2.5+4.2	1.57	1.57	1.57	1.97	3.31	4.36	10.00	11.67	0.67	2.04	2.52	3.20	9.40	11.53	95
	2.0+2.0+2.0+2.5+5.0	1.48	1.48	1.48	1.85	3.70	4.51	10.00	11.72	0.70	2.02	2.53	3.30	9.30	11.70	95
	2.0+2.0+2.0+2.5+6.0	1.38	1.38	1.38	1.72	4.14	4.82	10.00	11.98	0.75	2.02	2.62	3.50	9.30	12.10	95
	2.0+2.0+2.0+2.5+7.1	1.28	1.28	1.28	1.60	4.55	5.14	10.00	11.99	0.81	2.02	2.63	3.80	9.30	12.02	95
	2.0+2.0+2.0+3.5+3.5	1.54	1.54	1.54	2.69	2.69	3.87	10.00	11.66	0.59	2.05	2.53	2.80	9.40	11.70	95
	2.0+2.0+2.0+3.5+4.2	1.46	1.46	1.46	2.55	3.07	4.68	10.00	11.67	0.73	2.04	2.52	3.40	9.40	11.53	95
	2.0+2.0+2.0+3.5+5.0	1.38	1.38	1.38	2.41	3.45	4.83	10.00	11.72	0.75	2.02	2.53	3.50	9.30	11.70	95
	2.0+2.0+2.0+3.5+6.0	1.29	1.29	1.29	2.26	3.87	5.14	10.00	11.98	0.81	2.02	2.62	3.80	9.30	12.10	95
	2.0+2.0+2.0+4.2+4.2	1.39	1.39	1.39	2.92	2.92	4.83	10.00	11.63	0.76	2.03	2.50	3.50	9.30	11.50	95
	2.0+2.0+2.0+4.2+5.0	1.32	1.32	1.32	2.76	3.29	5.14	10.00	11.82	0.81	2.02	2.57	3.80	9.30	11.90	95
	2.0+2.0+2.5+2.5+2.5	1.74	1.74	2.17	2.17	2.17	4.04	10.00	11.66	0.62	2.04	2.53	2.90	9.40	11.60	95
	2.0+2.0+2.5+2.5+3.5	1.60	1.60	2.00	2.00	2.80	4.36	10.00	11.66	0.67	2.04	2.53	3.20	9.40	11.60	95
	2.0+2.0+2.5+2.5+4.2	1.52	1.52	1.89	1.89	3.18	4.52	10.00	11.67	0.70	2.03	2.52	3.30	9.40	11.52	95
	2.0+2.0+2.5+2.5+5.0	1.43	1.43	1.79	1.79	3.57	4.66	10.00	11.71	0.72	2.02	2.53	3.40	9.30	11.60	95
	2.0+2.0+2.5+2.5+6.0	1.33	1.33	1.67	1.67	4.00	4.98	10.00	11.97	0.78	2.02	2.62	3.70	9.30	12.10	95
	2.0+2.0+2.5+3.5+3.5	1.48	1.48	1.85	2.59	2.59	4.52	10.00	11.66	0.70	2.04	2.53	3.30	9.40	11.60	95
	2.0+2.0+2.5+3.5+4.2	1.41	1.41	1.76	2.46	2.96	4.84	10.00	11.67	0.76	2.03	2.52	3.50	9.40	11.52	95
	2.0+2.0+2.5+3.5+5.0	1.33	1.33	1.67	2.33	3.33	4.98	10.00	11.71	0.78	2.02	2.53	3.70	9.30	11.60	95
	2.0+2.0+2.5+4.2+4.2	1.34	1.34	1.68	2.82	2.82	4.99	10.00	11.62	0.78	2.03	2.50	3.70	9.30	11.50	95
	2.0+2.0+3.5+3.5+3.5	1.38	1.38	2.41	2.41	2.41	4.84	10.00	11.66	0.76	2.04	2.53	3.60	9.40	11.60	95
	2.0+2.0+3.5+3.5+4.2	1.32	1.32	2.30	2.30	2.76	5.00	10.00	11.67	0.79	2.03	2.52	3.70	9.40	11.52	95
	2.0+2.5+2.5+2.5+2.5	1.67	2.08	2.08	2.08	2.08	4.20	10.00	11.66	0.65	2.04	2.52	3.00	9.40	11.60	95
	2.0+2.5+2.5+2.5+3.5	1.54	1.92	1.92	1.92	2.69	4.36	10.00	11.66	0.67	2.04	2.52	3.20	9.40	11.60	95
	2.0+2.5+2.5+2.5+4.2	1.46	1.82	1.82	1.82	3.07	4.68	10.00	11.67	0.73	2.03	2.52	3.40	9.30	11.51	95
	2.0+2.5+2.5+2.5+5.0	1.38	1.72	1.72	1.72	3.45	4.82	10.00	11.71	0.75	2.02	2.53	3.50	9.30	11.60	95
2.0+2.5+2.5+2.5+6.0	1.29	1.61	1.61	1.61	3.87	5.14	10.00	11.97	0.81	2.02	2.62	3.80	9.30	12.10	95	
2.0+2.5+2.5+3.5+3.5	1.43	1.79	1.79	2.50	2.50	4.68	10.00	11.66	0.73	2.04	2.52	3.40	9.40	11.60	95	
2.0+2.5+2.5+3.5+4.2	1.36	1.70	1.70	2.38	2.86	5.00	10.00	11.67	0.79	2.03	2.52	3.70	9.30	11.51	95	
2.0+2.5+2.5+3.5+5.0	1.29	1.61	1.61	2.26	3.23	5.14	10.00	11.71	0.81	2.02	2.53	3.80	9.30	11.60	95	
2.0+2.5+2.5+4.2+4.2	1.30	1.62	1.62	2.73	2.73	5.15	10.00	11.62	0.81	2.03	2.50	3.80	9.30	11.50	95	
2.0+2.5+3.5+3.5+3.5	1.33	1.67	2.33	2.33	2.33	5.00	10.00	11.66	0.79	2.04	2.52	3.70	9.40	11.60	95	
2.5+2.5+2.5+2.5+2.5	2.00	2.00	2.00	2.00	2.00	4.36	10.00	11.65	0.67	2.04	2.52	3.20	9.40	11.60	95	
2.5+2.5+2.5+2.5+3.5	1.85	1.85	1.85	1.85	2.59	4.52	10.00	11.65	0.70	2.04	2.52	3.30	9.40	11.60	95	
2.5+2.5+2.5+2.5+4.2	1.76	1.76	1.76	1.76	2.96	4.83	10.00	11.66	0.76	2.03	2.51	3.50	9.30	11.49	95	
2.5+2.5+2.5+2.5+5.0	1.67	1.67	1.67	1.67	3.33	4.98	10.00	11.70	0.78	2.02	2.53	3.70	9.30	11.60	95	
2.5+2.5+2.5+3.5+3.5	1.72	1.72	1.72	2.41	2.41	4.84	10.00	11.65	0.76	2.04	2.52	3.50	9.40	11.60	95	
2.5+2.5+2.5+3.5+4.2	1.64	1.64	1.64	2.30	2.76	4.99	10.00	11.67	0.79	2.03	2.51	3.70	9.30	11.50	95	
2.5+2.5+3.5+3.5+3.5	1.61	1.61	2.26	2.26	2.26	5.16	10.00	11.69	0.82	2.04	2.53	3.80	9.40	11.57	95	